



February 11, 2016

MASTERCARE PATIENT EQUIPMENT INC
JAMES A NOVOTNE
2256 11TH AVE EAST
PO BOX 1435
COLUMBUS NE 68602-1435

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: MASTERCARE PATIENT EQUIPMENT INC
Product Name: MASTERCARE SIT BATH & ENTRÉE BATH (trans id 2651560)
Model Number(s): MB-50, MB-59-A, MB-59-AV, MB-60, MB-68, MB-68-A, MB-68-AI, MB-68-AV, MB-68-AVI,
MB68-I, MB-80-R, MB-80-RC, MB-80-RCR, MB-80, MB-80-C AND MB-80-CR
Product File No: 20160000

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2021.

This approval supersedes the approval issued on May 11, 2006 under product file number 20060062.

This approval is contingent upon compliance with the following stipulation(s):

- The reservoir tub fill must include a 1-11/16 inch opening to atmosphere with the top of the opening located at least 1-1/4 inches below the potable water discharge point into the reservoir.
- An ASSE 1035 compliant vacuum breaker must be installed in the water supply between the shut off valve for the cleaner disinfectant dispensing system and the cleaner disinfectant dispensing system.
- An ASSE 1014 compliant vacuum breaker must be installed in the water supply between the shower shut off valve and flexible hose serving the shower wand and the shower wand.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail