



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

March 7, 2016

ECOLAB, INC.
INSTITUTIONAL
ANI SEUMALO
370 N. WABASHA ST.
ST. PAUL MN 55102

Re: Description: PROPORTIONER
Manufacturer: ECOLAB, INC.
Product Name: (trans id 2662626) APEX DISPENSER
Model Number(s): APEX CENTER, APEX ELECTROMATIC POT & PAN DISPENSER, APEX RINSE
 DISPENSER, APEX DETERGENT DISPENSER, APEX HYDRAULIC POT & PAN
 DISPENSER and APEX HYDRAULIC PRESOAK DISPENSER
Product File No: 20160024

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.11, Wis. Adm. Code based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2021.

This approval supersedes the approval issued on January 3, 2011 under product file number 20110005.

This alternate approval is required because the devices are not listed under ASSE 1055.

No peripheral cross connection control is required for these devices because they incorporate pipe applied atmospheric vacuum breakers that conform to ASSE 1001.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail