



March 18, 2016

CREST PRECAST, INC.
STEVE MADER
609 KISTLER DR
LA CRESCENT MN 55947-1721

Re: Description: GREASE INTERCEPTOR
Manufacturer: CREST PRECAST, INC.
Product Name: (trans id 2674151) GREASE INTERCEPTOR
Model Number(s): 20000 GALS. (ONE- OR TWO-COMPARTMENT; 13,321/6,521 GALS.)

990 IN. L.L.; 223.57 GALS./IN.; 120 IN. MAX. DEPTH OF BURY; 20,121 GALS. ACTUAL CAPACITY; TANK DIMENSIONS =434 IN. L X 129 IN. W X 90 IN. H)

Product File No: 20160041

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.34 (5) c. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2021.

This approval supersedes the approval issued on February 21, 2011 under product file number 20110042.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Bedding: Tanks must be placed on soils capable of bearing the weight of tank and its contents, when full. Soft soils or bedrock must have 3 inches of tamped material, sand or gravel, 100% of which passes ½ -inch screen.
- This product is approved to use the following:
 - Neenah Foundry gasketed access cover.
 - Bilco locking hinged access cover.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Dual 6-in. diameter inlets at end of tank with one access opening above both inlets.
 - Dual 6-in. diameter outlets at end of tank with one access opening above each outlet.
 - Pipe ports at 4-, 6- or 8-inch diameter.
 - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Riser openings at 24-, 35- or 48- inch rectangle or min. 24-inch clear opening for square.

Crest Precast Incorporated
March 18, 2016
Page 2 of 2
Product File No.: 20160041

- Backfill: Sidewall-backfill must consist of material 100% of which will pass through a 2-in. screen and be made up of dry soil, sand or gravel. A minimum (avg.) of 12 inches on all sides of the tank from base to top is recommended. No parallel backfilling or compaction along the sidewalls is recommended. No wheel-tracking or track loading on sidewalls is recommended. Cover-backfill up to 7-feet of loading must be dry and pass through 4-inch screen.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail