



Scott Walker, Governor
Dave Ross, Secretary

March 09, 2016

Identification Numbers
Transaction ID No. 2673079
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1343222

PATRICK MULHALL
POLYLOK INC
3 FAIRFIELD BLVD
WALLINGFORD CT 06492

PLAN APPROVAL EXPIRES: 03/31/2021

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER
 Manufacturer: POLYLOK INC./ZABEL
 Product Name: (trans id 2673079) POLYLOK HIGH PRESSURE EFFLUENT FILTER
 Model Number(s): 3014-PF, 3014-SS
 AVAILABLE AS 1/16 IN. SLOT OR STAINLESS STEEL WITH OPTIONAL 60 OR 100 MICRON FILTER SOCK FOR PRESSURIZED POWTS SYSTEMS ONLY [CLEAN AND MAINTAIN EACH TIME TANK IS PUMP, BUT AT LEAST AT 3-YEAR INTERVAL; PROVIDES > 1/16 IN. FILTRATION; MORE FREQUENT REPLACEMENT OF FILTER SOCK; 0.5 FT. HEAD LOSS; MOUNTED DIRECTLY TO DISCHARGE END OF AWNY PUMP]
 Product File No: 20160050

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2021.**

This approval supersedes the approval issued on 9/4/2010 under product file number 20100290.

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- MAINTENANCE: The manufacturer recommends this unit be cleaned every time the tank is pumped or at least once every three years.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S., POWTS Product Reviewer
phone: (608) 267-5265, fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:
www.surveymonkey.com/s/dspsiscustomersatisfaction