



Scott Walker, Governor
Dave Ross, Secretary

March 09, 2016

Identification Numbers
Transaction ID No. 2673077
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1343222

PATRICK MULHALL
POLYLOK INC
3 FAIRFIELD BLVD
WALLINGFORD CT 06492

PLAN APPROVAL EXPIRES: 03/31/2021

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER
 Manufacturer: POLYLOK INC./ZABEL
 Product Name: (trans id 2673077) EFFLUENT FILTER
 Model Number(s): 3014-525 and 3014-625
 Prevents solids >1/16 in. dia. and >1/32 in. dia., respectively from passing.
 [MAX. DWF = 10,000 GPD; FITS 4- OR 6-IN. DIA. OUTLET]
 Product File No: 20160055

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2021.**

This approval supersedes the approval issued on 6/2/2010 under product file number 20100245.

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- MAINTENANCE: Clean filter at inspection/pumping interval.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPPS is committed to service excellence. Visit our survey at:
www.surveymonkey.com/s/dspscustomersatisfaction