



April 6, 2016

MEDCO EQUIPMENT INCORPORATED
PHILLIP BROOKSBANK
30 HILLTOP ROAD
HOULTON WI 54082

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: MEDCO EQUIPMENT INCORPORATED
Product Name: (trans id 2686206) MEDCO WHEELCHAIR WASHER
Model Number(s): 64 AND 64X
Product File No: 20160097

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2021.

This approval is contingent upon compliance with the following stipulation(s):

- These devices shall be served by floor drains or receptors, in accordance with s. SPS 382.33 (8), such that nuisances are not created. The DWV system shall be adequately sized to receive the additional wastewater flow generated by these devices.
- A cross connection control device suitable for high hazard shall be installed on the fixture supply lines serving these devices. If these devices are installed in a continuous pressure situation (under pressure for ≥ 12 hours per day), then a hose connection vacuum breaker (ASSE 1011) may not be used.
- If a pressure vacuum breaker or reduced pressure principle cross connection control devices are used, then the assemblies shall be registered and tested in accordance with s. SPS 382.22 (8) Wis. Adm. Code, and installed in conformance with s. SPS 382.41 (5) Wis. Adm. Code.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail