



Scott Walker, Governor
Dave Ross, Secretary

June 30, 2016

Identification Numbers
Transaction ID No. 2688487
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1336904

TODD BOGENRIEF
CONTAINMENT SOLUTIONS INC
9505 GENEVIEVE DR
ST JOHN IN 46373

PLAN APPROVAL EXPIRES: 06/30/2021

Re: Description: SEWAGE TANKS, FIBERGLASS
 Manufacturer: CONTAINMENT SOLUTIONS, INC.
 Product Name: (trans id 2688487) SEPTIC, HOLDING, PUMP, SIPHON OR SEPTIC TANK EFFLUENT PUMP SYSTEM (STEPS)
 Model Number(s): SWT G-6 (8') 8,000 gallon single wall (50.0 IN. L.L.; 7796 GALLONS ACTUAL CAPACITY; 7 FT. MAX. DEPTH OF BURY; TANK DIMENSIONS = 24' 11 IN. L X 92 IN. DIA.; SEE ATTACHMENT FOR GAL./IN. IN ONE-INCH INCREMENTS AND BEDDING/BACKFILL INSTRUCTIONS)
 Product File No: 20160106

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of June 2021.**

This approval supersedes the approval issued on 5/2/2016 under product file number 20110114.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- When this product receives wastewater from dwellings and is used as a septic tank effluent pump system, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS, F.O.G. of less than 30 mg/L and solids of 1/8 inch or less.

- When this tank is used a septic tank effluent pump system, the capacity and float levels must comply with the follow requirements:
 1. A treatment zone equal to at least 2.088 times the design wastewater flow entering the tank,
 2. A drawdown zone based on the system design, and
 3. A one-day reserve zone above the high water alarm level based on the estimated wastewater flow.
- This product is approved to use the following:
 - Variable sealable opening through tank risers for electrical or pump discharge connections.
 - Department approved effluent filters installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Lower end pipe openings for septic, siphon, pump, holding or STEPS tank installations.
 - Department approved risers installed in accordance with the product approval for the riser.
 - 24", 30" or 48" diameter PVC riser with cover attached using an acceptable locking device.
- When this tank is used a septic tank, the gallon per day design treatment capacity based on a 3-year service interval for residential wastewater equals the tank capacity divided by 2.088.
- OPTIONAL DEEPER TANK BURY DEPTH: For installations requiring a deeper tank burial depth than max. 7-foot, contact CONTAINMENT SOLUTIONS. Tank wall thickness, and end cap will be increased during in-plant tank construction. See also tank installation instructions, INST 6001G.
- Additional information is included as attachment(s) to this letter.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction