



June 30, 2016

GREEN4ALL ENERGY SOLUTIONS INC.  
DAN HANDLEY  
30 S. WACKER DR. - SUITE 2200  
CHICAGO IL 60606

Re: Description: ALTERNATE PRODUCT REVIEW  
Manufacturer: GREEN4ALL ENERGY SOLUTIONS INC.  
Product Name: (trans id 2699677) H2 MINUS 0  
Model Number(s): H2-3/4", 1", 1 1/2", 2", 3", 4", 6", 8", 10" AND 12"  
Product File No: 20160121

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (5) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2021.

This approval supersedes the approval issued on November 6, 2013 under product file number 20130133.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The Water Supply (water fittings) regulations 1999 are designed for the prevention of waste, undue consumption, misuse or contamination of the drinking water. The Water Regulations Advisory Scheme (WRAS) specifies test to determine whether products used on consumer premises conform to the Regulations. For non-metallic products the WRAS uses the methods and criteria in BS6920:2000. This product conforms to this listing.

It has been determined by this office that this listing is equivalent to NSF 61. (Drinking Water System Components Health Effects) This approval is for material safety only.

**This approval is not an approval for advertised performance claims made for these devices by the manufacturer.**

- A properly sized electrical bonding jumper shall be installed such that the electrical continuity of the path to ground is maintained when these devices are installed on metallic water supply systems being used as an electrical ground.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail