



**Scott Walker, Governor**  
**Dave Ross, Secretary**

May 04, 2016

Identification Numbers
<b>Transaction ID No. 2702041</b>
<b>Site ID No.</b>
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1349337

STEVEN SABO  
HYDRO ACTION SALES MANAGER  
2055 PIDCO DR PO BOX 640  
PLYMOUTH IN 46563

**PLAN APPROVAL EXPIRES: 05/31/2021**

Re: Description: SEWAGE TANKS, FIBERGLASS  
Manufacturer: HYDRO-ACTION  
Product Name: (trans id 2702041) PUMP  
Model Number(s): 500 GALLON  
(51.0 L.L; 8.32 GAL/IN., 18 IN. MAX. DEPTH OF BURY; TANK DIMENSIONS =  
47.91 IN. DIA. X 51.0 IN. H)  
Product File No: 20160129

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of May 2021.**

This approval supersedes the approval issued on 9/7/2011 under product file number 20110264.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, the plan approval and s. SPS 383.15 (4), Wis. Admin. Code. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval and code requirements will take precedence.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The manhole cover shall be provided with a locking device that conforms to s. SPS 384.25 (7)(h) of the Wisconsin Administrative Code.

- Bedding: Tanks must be placed on suitable soils capable of bearing the weight of tank and contents when full. Soft soils or bedrock must have 6 inches of tamped material, sand or pea gravel.
- Backfill: Fill must be free flowing soil or gravel of no larger than  $\frac{3}{4}$  inch. Fill tanks with water while backfilling. Compact soil in 2-foot increments until backfill is at grade.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

[www.surveymonkey.com/s/dspsiscustomersatisfaction](http://www.surveymonkey.com/s/dspsiscustomersatisfaction)