



July 6, 2016 (Reissued December 20, 2016)

C.E.C.
DALE SCHLIEVE
312 CONRO ST.
RHINELANDER WI 54501

ONEIDA CONCRETE PRODUCTS, INC.
CHAD JOHNSON
171B CHIPPEWA DR.
PO BOX 357
RHINELANDER WI 54501

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: ONEIDA CONCRETE PRODUCTS, INC.
Product Name: (trans id 2711451) SEPTIC, PUMP OR HOLDING
Model Number(s): 758
(36.5 IN. L.L., 20.62 GAL/IN., **72 IN.** MAX. DEPTH OF BURY, 363 G.P.D. WHEN USED AS
A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER; TANK DIMENSIONS (OD) = 82 IN. L X 62 IN. W X 53 IN. H)
Product File No: 20160147

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2021.**

This approval supersedes the approval issued on 6/10/2011 under product file number 20110185.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- The products produced by this manufacturer are approved to use the following:
 - One-inch schedule 40 PVC cast in riser for electrical wiring.
 - Bottom openings for holding tank and for pump tank or compartment.
 - Department approved effluent filter designed installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Access opening cover with 4-inch opening.
 - Press Seal "Cast-A-Seal" by Press Seal Gasket Corp.
 - Department approved plastic risers and covers.
- Tank Bedding: As per manufacturer's instructions, provide min. of 6 inches pea stones free of debris, sharp stones and stones greater than 2 inches in diameter.
- Bedding: tank shall be placed with a min. of 3 in. sand pad or gravel.

C.E.C.
Page 2
July 6, 2016 **(Reissued December 20, 2016)**
Product File No: 20160147

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction