



July 11, 2016

BIO-MICROBICS, INC.
JIM BELL
8450 COLE PKWY.
SHAWNEE KS 66227

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER
Manufacturer: BIO-MICROBICS, INC.
Product Name: (trans id 2711945) SANITEE
Model Number(s): SNT 416, SNT 418
[4 IN. DIA., FLOW RANGE UP TO 1000 GPD AND 2000 GPD, RESPECTIVELY;
SCREENS PARTICLES UP TO 1/16 IN. AND 1/8 IN., RESPECTIVELY]
Product File No: 20160155

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2021.**

This approval supersedes the approval issued on 10/17/2011 under product file number 20110312.

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- This product must be installed in sewage treatment tanks approved by the Department of Safety & Professional Services, Division of Industry Services for use with this product.
- A means of venting the gases formed inside of the tank in which this product is installed shall be provided in accordance with s. sps 384.25 (5), of the Wisconsin Administrative Code.
- This product must be installed in accordance with the manufacturer's installation instructions and with the bottom of the product above the scum level in the tank.
- This product shall be cleaned and maintained at the same time as the tank pumping interval.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DPS is committed to service excellence. Visit our survey at:
www.surveymonkey.com/s/dpsiscustomersatisfaction