



July 11, 2016

KNIGHT TREATMENT SYSTEMS
MARK C NOGA, PRES.
281 COUNTY ROUTE 51A
OSWEGO NY 13126

Re: Description: SEWAGE TREATMENT APPARATUS (Tier 3- downsizing & vertical separation credit)
Manufacturer: KNIGHT TREATMENT SYSTEMS
Product Name: (trans id 2715491) WHITE KNIGHT MICROBIAL INOCULATOR/GENERATOR
Model Number(s): WK-150 AND WK-200
ENHANCED BIOLOGICAL INNOCULATOR GENERATOR; THIS APPROVAL AND ITS CONDITIONS ARE LIMITED TO USE & INSTALLATION IN NEW POWTS SYSTEM DESIGNS; SEE SPECIFIC CONDITIONS FOR RESIDENTIAL WASTEWATER AND HIGH STRENGTH WASTE/COMMERCIAL

[WK-150: MAX. DWF 2000 GALS./DAY; RESIDENTIAL STRENGTH WASTEWATER; MIN. TANK CAPACITY = 3000 GAL. or 1.5-DAY RESIDENCE TIME WITH 2-DAY RESIDENCE TIME PREFERRED; NOTE: THE WK-150 IS ONE WK-40 AND ONE WK-78 INSTALLED IN A SERIES; SEE ATTACHMENT FOR INSTALLATION SKETCH]

[WK-200: MAX. DWF 2400 GALS./DAY; RESIDENTIAL STRENGTH WASTEWATER; FOR HIGH STRENGTH WASTEWATER/COMMERCIAL USE; MIN. TANK CAPACITY = 4000 GALS. or 1.5-DAY RESIDENCE TIME WITH 2-DAY RESIDENCE TIME PREFERRED; NOTE: THE WK-200 IS TWO WK-78 INSTALLED IN A SERIES; SEE ATTACHMENT FOR INSTALLATION SKETCH]

MAX. BOD5 1500 MG/L/DAY; FOR AVG. F.O.G. SEE STIPULATIONS REGARDING TREATMENT TRAIN.

Product File No: 20160157

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2021.**

This approval supersedes the approval issued on 7/26/2011 under product file number 20110173.

This approval is contingent upon compliance with the following stipulation(s):

- This product must be utilized in accordance with the manufacturer's printed installation instructions and this product approval. If there is a conflict between the manufacturer's installation instructions and the product approval, the product approval requirements will take precedence.
- The minimum depth of unsaturated soil for treatment purposes of the treatment/dispersal cell that receives wastewater from this product must comply with the vertical distance listed in Table 383.44-3 under Fecal Coliform equal to or less than 10,000 cfu/100ml column heading.
- A copy of this approval letter and the manufacturer's printed installation instructions must be supplied to the buyer of this product.
- The outlet baffle of the septic tank, which has this product installed, must have installed an effluent filter capable of filtering particles of 1/8 inch in size or larger.

- This product must be installed by a properly licensed plumber.
- A state Sanitary Permit must be obtained when this product is installed.
- The IOS-500 inoculant must be exchanged at least on an annual basis.
- Prior to installation of this product, plans and specifications must be submitted to the department or to an approved agent municipality for review and approval in accordance with s. SPS 382.20 (1) of the Wis. Admin. Code. Written approval for the plans and specifications shall be obtained prior to installation of the product.
- AS OF MARCH 1, 2009 ALL ELECTRICAL CONNECTIONS FOR PRIVATE SEWAGE SYSTEMS MUST COMPLY WITH S. SPS 316.300 (formerly S. COMM 16.300), WIRING METHODS.
- An access opening of sufficient size to allow installation, inspection maintenance and servicing of this device/product must be provided. This access opening must terminate at or above grade.
- When this product is included in a POWTS designed to meet Table SPS 383.44-3 and receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L, F.O.G. of less than or equal to 30 mg/L and fecal coliform of less than or equal to 10,000 cfu/100 ml.
- This approval for the above-referenced PRODUCT FILE No. does not provide for the inclusion of this product in an existing failing POWTS; products to rejuvenate failing POWTS must have separate approval by DSPS for chemical or physical restoration (CPR). [s. SPS 383.53].
- For commercial use in establishments with food service, full service restaurants, and similar facilities, state-approved upstream grease interceptor of an acceptable size and treatment performance must be installed to bring wastewater parameters to acceptable levels: FOG – 200 mg/L. Tank must allow for min. of 2-day residency time of average DWF with a suggested min. capacity of 1500 gallons.
- Table 1 Maintenance, Inspection, Pumping Requirements
WHITE KNIGHT MICROBIAL INOCULATOR/GENERATOR™
PRODUCT/ (Models) WK-150, WK-200.....
Initial/Startup Inspection/ Maintenance-- service agreement may be
required by manufacturer; replace IOS-500 inoculant annually
Ongoing Pumping Cycle And/Or Requirements N/A
Back-Wash Cycle N/A
Effluent Performance Levels NO (NSF Class I)
BOD5 Credit For Downsizing Distribution Area YES
Fecal Credit For Reduction Of Vertical Separation YES
Additional Comments
- PUMPS AND TOWERS: The WK-150 uses a single alarm panel and air pump (Hiblow HP 150) sufficient to provide air volume and pressure to power three WHITE KNIGHT MIG® Towers. The WK-200 uses a single alarm panel and air pump (Hiblow HP 200) sufficient to provide air volume and pressure to power four WHITE KNIGHT MIG® Towers.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:
www.surveymonkey.com/s/dspscustomersatisfaction