



June 16, 2016

PRIER PRODUCTS, INC  
SCOTT BRADY  
4515 E 139TH ST  
GRANDVIEW MO 64030

Re: Description: HYDRANT, ANTI-BACKFLOW, WALL - ASSE 1019  
Manufacturer: PRIER PRODUCTS, INC  
Product Name: (trans id 2716143) WALL HYDRANTS WITH ASSE 1019-C  
Model Number(s): C-144, M-400 AND P-164  
Product File No: 20160160

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (5) (c) 12. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2021.

This approval supersedes the approval issued on October 11, 2011 under product file number 20110308.

This alternate approval is required because s. SPS 384.30 (5) (c) 12. does not acknowledge the ASSE 1019-C designation.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The hose shall be removed to protect against damage from freezing.
- Each hydrant shall have the following information marked on it where it is visible after the hydrant has been installed:
  1. Manufacturer's name or trademark;
  2. Model number designation; and
  3. "Type C."

The markings shall be cast, etched, stamped or engraved on the body of the hydrant, or on a brass or stainless steel plate securely attached to the device by a corrosion resistant means.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail