



Scott Walker, Governor
Dave Ross, Secretary

August 29, 2016

Identification Numbers
Transaction ID No. 2723915
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1352957

PATRICK TORRES
ORENCO SYSTEMS INC
814 AIRWAY AVE
SUTHERLIN OR 97479

CONDITIONAL APPROVAL
PLAN APPROVAL EXPIRES: 08/31/2021

Re: Description: SEWAGE TREATMENT APPARATUS, FILTER CONTAINER/VAULT
Manufacturer: ORENCO SYSTEMS INC
Product Name: (trans id 2723915) 18 IN. DIA. EXTERNAL EFFLUENT FILTER BASIN, PVC
Model Number(s): FTB 18XX-yyzz

WHERE XX = basin height, yy = filter diameter, zz = filter cartridge height)
(Variable L.L., volume calculation using 1.06 gal./in., 13 FT. MAXIMUM BURY
DEPTH MEASURED TO BOTTOM OF BASIN)

Product File No: 20160166

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2021.**

This approval supersedes the approval issued on 2/10/2010 under product file number 20100011.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPPS is committed to service excellence. Visit our survey at:
www.surveymonkey.com/s/dspsiscustomersatisfaction