



June 24, 2016

KOHLER COMPANY
THOMAS KRAMER
444 HIGHLAND DRIVE
KOHLER WI 53044

Re: Description: IN-WALL TANK AND CARRIER SYSTEM
Manufacturer: KOHLER COMPANY
Product Name: (trans id 2723946) IN-WALL TANK AND CARRIER SYSTEM
Model Number(s): K-6284 AND K-18829
Product File No: 20160170

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.31 (9) (a) 2. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2018.

This approval supersedes the approval issued on December 17, 2013 under product file number 20130365.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The use of the K-18829 carrier unit is limited to the following specific bowls:
 1. K-6300 Veil
 2. K-6299
- The use of the K-6284 carrier unit is limited to the following specific bowls:
 - a. K-6303 Veil
 - b. K-6304 Veil
- Venting of these carrier units shall conform to s. SPS 382.31 (9) (a) 2. Wis. Adm. Code. Fixture drains installed in the vertical position shall be installed in accordance with the venting requirements for floor outlet water closets and the vertical distance between the water level in the bowl and the centerline of the horizontal portion of the drain shall be ≤ 36 inches as outlines in SPS 382.32 (4) (b) 1. c. Fixture drains installed in the horizontal position are subject to the venting limitations specified in s. SPS 382.31 (10).
- These systems shall be installed in accordance with the manufacturer's published "Installation and Care Guide" 11429989-2-B or 1142998-2-D.
- Approval is issued for these products as being equivalent to a floor outlet water closet when the fixture drain is installed in the vertical position. The design meets the intent of s. SPS 382.32 (5) (c) and 384.20 (5) (n), Wis. Adm. Code, which requires water closets to discharge through a minimum 3-inch diameter pipe or fitting and the bowls conform to ANSI Standard A112.19.2M. The intent of the code is met since the performance of these products are functionally identical to water closet that meet ANSI Standard A112.19.2M.

Kohler Company
June 24, 2016
Page 2 of 2
Product File No.: 20160170

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail