



Scott Walker, Governor
Dave Ross, Secretary

June 30, 2016

Identification Numbers
Transaction ID No. 2723919
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1352957

PATRICK TORRES
ORENCO SYSTEMS INC
814 AIRWAY AVE
SUTHERLIN OR 97479

PLAN APPROVAL EXPIRES: 06/30/2021

Re: Description: SEWAGE TREATMENT APPARATUS
Manufacturer: ORENCO SYSTEMS INC
Product Name: (trans id 2723919) EFFLUENT SCREENS
Model Number(s): NON-ADJUSTABLE MODELS: ES1540, ES1548, ES12510, ES1840, ES1848, ES1860, ES2040, ES2048, ES2060, ES2440, ES2448, ES2460 [All Non-Adjustable models have the option of a Float Bracket (FB) and/or Flow Inducer (FI)] [>1/8 IN. FILTRATION]
ADJUSTABLE MODELS: E15A, E18A, E20A, 20AFI [All Adjustable models have the option of a Float Bracket (FB) or Flow Inducer (FI)] [>1/8 IN. FILTRATION]
Product File No: 20160171

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of June 2021.**

This approval supersedes the approval issued on 1/20/2011 under product file number 20110029.

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product must be installed in sewage treatment tanks approved by the Department of Safety & Professional Services, Division of Industry Services for use with this product.
- MAINTENANCE: Clean filter at inspection/pumping interval.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction