



August 2, 2016

REVISED COPY

PROVENT SYSTEMS, INC.  
KEN CORNWALL  
1355 CAPITAL CIRCLE  
LAWRENCEVILLE GA 30043

Re: Description: PLUMBING ENGINEERED SINGLE STACK SYSTEM, ALTERNATE PLUMBING SYSTEM  
Manufacturer: PROVENT SYSTEMS, INC.  
Product Name: (trans id 2725426) PROVENT SINGLE STACK SYSTEM  
Model Number(s): P4542-SD, P4542-SL, P4542-SR, P3542-SD, P3542-SL, P3542-SR, P4542-B AND  
P3542-B  
Product File No: 20160180

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.31 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2019.

This approval supersedes the approval issued on July 17, 2014 under product file number 20140087.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The entire system must be designed and installed in accordance with the 2014 copyright, plus 2016 revisions, ProVent Systems Inc. ProVent Guide to Design and Usage manual requirements and recommendations.
- Written approval for the plumbing plans shall be obtained from the department for each installation of this system. If the project is located within the city of Milwaukee, plans may be submitted to either the department or to the city of Milwaukee.
- A cleanout shall be installed on the pressure relief line.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail