



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

July 7, 2016

ACORN ENGINEERING COMPANY
FARHAD SHAHRIARY
15125 PROCTOR AVE
CITY OF INDUSTRY CA 91746

Re: Description: FAUCET, LAVATORY
Manufacturer: ACORN ENGINEERING COMPANY
Product Name: (trans id 2731842) MANIFOLDED AIR CONTROL VALVE ASSEMBLY
Model Number(s): -03-MA2, -03-MA3, -03-MA4, -04-MA2, -04-MA3 AND -04,MA4
Product File No: 20160184

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.40 (4) (c) 1. b. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2021.

This approval supersedes the approval issued on March 30, 2016 under product file number 20110293.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Approval is issued for this product because the design of the product meets the intent of s. SPS 382.40 (4) (c) 1. b., Wis. Adm. Code that requires a control valve in fixture supply to each plumbing fixture. The intent of the code is met since this product provides an acceptable method of valving up to four lavatory faucets in a penal setting.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail