



September 14, 2016

ICC EVALUATION SERVICE LLC  
WESTERN REGIONAL OFFICE  
MARIBEL CAMPOS  
3060 SATURN STREET, STE. 100  
BREA CA 92821

SCHLUTER SYSTEMS  
SCHLUTER SYSTEMS LP  
RUTH ZOSCHKE  
194 PLEASANT RIDGE ROAD  
PLATTSBURGH NY 12901

Re: Description: SHOWER ALTERNATE  
Manufacturer: SCHLUTER SYSTEMS  
Product Name: (trans id 2736116) SCHLUTER SHOWER SYSTEM  
Model Number(s): SCHLUETER-KERDI DRAINS, SCHLUTER KERDI-SHOWER-ST PREFABRICATED  
FOAM TRAYS, SCHLUETER-KERDI BOARDS WATER PROOF BUILDING PANELS,  
SCHLUTER-KERDI WATER PROOFING MEMBRANES AND SCHLUTER-KERDI-LINE  
Product File No: 20160186

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (6) (f) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2021.

This alternate approval is contingent upon compliance with the following stipulation(s):

- KERDI water proofing membrane shall be installed to a minimum height  $\geq$  the height of the showerhead.
- Any penetrations of the KERDI water proofing membranes shall be treated with a suitable sealant.
- The specific waterproofing membranes approved for use with the Schluter Shower System are:
  1. Schluter-Kerdi
  2. Schluter-Kerdi-DS
  3. Schluter-Ditra
  4. Schluter-Ditra-XL
  5. Schluter-Ditra-Heat
  6. Schluter-Ditra-Heat-TB

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail