



August 18, 2016

STRATFORD HOMES LTD.
PAUL SCHROEPFER
PO BOX 37
STRATFORD WI 54484

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: STRATFORD HOMES LTD.
Product Name: (trans id 2742154) PRE-FAB PLUMBING
Model Number(s): SH-10-92 W/T-5
Product File No: 20160200

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2021.

This approval supersedes the approval issued on August 18, 2011 under product file number 20110259.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 20 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.
- All plumbing system components that contact potable water that may be consumed shall conform with NSF 372 or NSF Standard 61, section 9.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail