



**Scott Walker, Governor**  
**Dave Ross, Secretary**

September 29, 2016

Identification Numbers
<b>Transaction ID No. 2762913</b>
<b>Site ID No.</b>
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1315038

BRIAN BORDERS  
QUANICS INC  
PO BOX 1520  
CRESTWOOD KY 40014

**CONDITIONAL APPROVAL**  
**PLAN APPROVAL EXPIRES: 09/30/2021**

Re: Description: SEWAGE TANK COVERS, LIDS, RISERS  
Manufacturer: QUANICS, INC.  
Product Name: (trans id 2762913) ZEUS ACCESS SYSTEM RISERS AND LIDS  
Model Number(s): RISERS: 22 INCH: RB-L-22; RB-RTA-22X2; RB-CTA-22X6; RB-R-22X6; RB-R-22X12 and RB-R-22X38;  
26 INCH: RB-L-26; RB-RTA-26X2; RB-CTA-26X6; RB-R-26X6; RB-R-26X12 and RB-R-26X38  
TANK ADAPTER: RB-PTA-26X2

**[CAST-IN OR RETROFIT HDPE RISERS IN MULTIPLE HEIGHTS AND NEOPRENE GASKETS]**

**Product File No: 20160210**

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of September 2021.**

This approval supersedes the approval issued on 8/2/2011 under product file number 20110233.

This approval is contingent upon compliance with the following stipulation(s):

- The manhole cover must be secured to the riser using screws which are not standard or Phillips head to be considered an effective locking device.
- Before this product is installed a warning label meeting the requirement of SPS s. 384.25 (8) (b), Wis. Admin. Code must be securely attached to the manhole cover.
- Joints between riser sections shall be sealed with neoprene gasket supplied by the manufacturer and the riser must be installed on state-approved tanks in accordance with the riser manufacturer's installation instructions.
- For high groundwater installations, refer to manufacturer's installation recommendations.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S., POWTS Product Reviewer  
phone: (608) 267-5265, fax: (608) 267-9723, email: [glen.jones@wi.gov](mailto:glen.jones@wi.gov)

The DSPS is committed to service excellence. Visit our survey at:  
[www.surveymonkey.com/s/dspscustomersatisfaction](http://www.surveymonkey.com/s/dspscustomersatisfaction)