



October 17, 2016

DEMA ENGINEERING CO.
ENGINEERING
SONE CHAN
10020 BIG BEND BLVD.
ST. LOUIS MO 63122

Re: Description: PROPORTIONER
Manufacturer: DEMA ENGINEERING CO.
Product Name: (trans id 2777393) BLEND CENTERS
Model Number(s): 633AG-1, 633AG-4, 635AG-1, 635AG-4, 637AG-1, 637AG-4, 639AG-1, 639AG-4, 661AG-4, 661AGB, 661AGDB, 662-AG-1, 662-AG-4, 662-2AGDB-11, 662-2AGDB-14, 662-2AGDB-44, 662-2AG-11, 662-2AG-14, 662-2AG-44, 662-3AG-1, 662-3AG-114, 662-3AG-144, 662-3AG-4, 662-4AG-1111-2, 662-4AG-1114-2, 662-4AG-1144-2, 662-4AG-1111-4, 662-4AG-1114-4, 662-4AG-1144-4, 662-635AG-1, 662-635AG-4, 662-637AG-1, 662-637AG-4, 662-639AG, 681AG-1, 681AG-2, 681AG-3, 681AG-4, AND 681AG-5
Product File No: 20160242

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.41 (3) (a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2021.

This approval supersedes the approval issued on August 8, 2012 under product file number 20120288.

This alternate approval is contingent upon compliance with the following stipulation(s):

- These products may be installed in conjunction with faucets manufactured by Chicago Faucet, Fisher Manufacturing or T&S Brass to provide the faucet connection for the DEMA Blend Center via a 163AG or 164AG air gap proportioner.
- The fixture supply hose used to connect the proportioners to these products shall conform with NSF 61 or NSF 51 and have a temperature/pressure rating \geq 100 psig @ 180° F.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail