



October 31, 2016 **(Reissued - December 15, 2016)**

MEADE CONCRETE COMPANY LLC  
JOHN MEADE  
W10440 COUNTY ROAD K  
PO BOX 167  
LODI WI 53555

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: MEADE CONCRETE COMPANY LLC  
Product Name: (trans id 2786862) SEPTIC, PUMP, SIPHON OR HOLDING  
Model Number(s): 1000  
(37" L.L., 27.01 GAL/IN., 72 IN. MAX. DEPTH OF BURY REQUIRES 6 IN. REINFORCED COVER, >72 IN. TO <120 IN. MAX. DEPTH OF BURY REQUIRES 8 IN. REINFORCED COVER, 479 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER TANK DIMENSIONS (OD) = 117 IN. L X 68 IN. W X 54/56 IN. H)  
Product File No: 20160256

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2021.**

This approval supersedes the approval issued on 10/24/2011 under product file number 20110316.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Pipe materials constructed in conformance with Table 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Four inch inlet through cover of tank for holding
  - Four inch inlet or discharge opening in riser.
  - Six inch inlet and outlet openings.
  - Press Seal "Cast-A-Seal" by Press Seal Gasket Corp.
  - Dual inlets and outlets at end of tank with one access opening above each inlet.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.

MEADE CONCRETE COMPANY LLC

Page 2

October 31, 2016 **(Reissued - December 15, 2016)**

Product File No: 20160256

- **BEDDING:** A 3-inch thick compacted bedding must be provided for all septic and other treatment tanks. The bed material must be a dry, sandy loam material or coarser, of such size that will pass a ½-in. screen.
- **BACKFILL:** The backfill must be dry soil material such that 100% will pass a 4-in. screen and must be tamped into place.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov