



October 27, 2016

ALIAxis LLC
IPEX USA LLC
CHARLIE LOTH
1408 E BAILEY ROAD
NAPERVILLE IL 60565

ALIAxis
CANPLAS INDUSTRIES LTD.
ANDREW BIRD
500 VETERANS DRIVE
BARRIE ONTARIO L4N 9J5
CANADA

Re: Description: EXTERIOR GREASE INTERCEPTOR
Manufacturer: ALIAxis
Product Name: (trans id 2786886) ENDURA GREASE INTERCEPTORS
Model Number(s): 3907A, 3910A, 3915A, 3920A, 3925A, 3925ALT, 3925AXT, 3935A, 3950A, 4075A AND 40100A
Product File No: 20160264

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.34 (5) (c) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2021.

This alternate approval is contingent upon compliance with the following stipulation(s):

- These interceptors shall be clearly and legibly marked with the following minimum information:
 1. Maximum liquid capacity
 2. Name and address and/or registered trademark of the manufacturer.

The markings shall be impressed into or embossed onto the outside wall immediately above the outlet opening.

- The mfg. shall maintain conformance to ASME A112.14.3 for these interceptors.
- A sampling manhole or open top outlet diffuser shall be installed in the discharge piping of the interceptor.
- No flow control device shall be installed in the inlet piping serving the interceptor.
- The interceptor shall be protected from freezing.
- Sizing shall be done by capacity and in accordance with the manufacturer's method as displayed in attachment A.
- These interceptors shall be preceded by a solids separator.
- Shall discharge to Municipal Sewers only. Shall not discharge to a Private Onsite Wastewater Treatment Systems.
- Maximum depth of bury from top of interceptor to grade, 72 inches.
- If multiple interceptors are installed an inlet manifold method will be used with the ability to clean **ALL** horizontal piping.

Aliaxis – Canplas Industries Ltd.
October 27, 2016
Page 2 of 2
Product File No.: 20160264

- This alternate may be rescinded by the Department at any time if performance of the interceptors is deemed to be unacceptable

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail