



November 16, 2016

GROVE CONCRETE & SUPPLY INC.  
PAUL MILLER JR./ SUSAN SMITH  
18426 DURAND AVE  
PO BOX 363  
UNION GROVE WI 53182

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: GROVE CONCRETE & SUPPLY INC.  
Product Name: (trans id 2789120) SEPTIC, HOLDNG OR PUMP  
Model Number(s): 7724 (SEPTIC) 7855 OR 8379 (HOLDING)  
(118 IN. L.L., 65.5 GAL/IN., 48 IN. MAX. DEPTH OF BURY, 3699 G.P.D. WHEN USED AS  
A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL  
WASTEWATER; TANK DIMENSIONS = 192 IN. L X 96 IN. W X 118 IN. H)  
Product File No: 20160285

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2021.

This approval supersedes the approval issued on September 19, 2011 under product file number 20110283.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - Pipe materials constructed in conformance with Table 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Four or six inch inlet and outlet openings.
  - Press Seal "Cast-A-Seal" by Press Seal Gasket Corp. and Polylok II High Pressure Pipe Seal by Polylok.
  - Dual inlets at end or side of tank with access opening above each inlet baffle.
  - Four inch discharge opening in riser.
  - 2-1/2 inch threaded nipple cast in riser for electrical wiring.
  - Four, six or eight inch pipe openings located near the bottom of the side or end wall for pump and holding tanks.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- AS OF MARCH 1, 2009, SECTION SPS 384.10 (FORMERLY COMM 84.10) WAS MODIFIED AND THE REVIEW OF EXTERIOR GREASE INTERCEPTORS AS A PLUMBING PRODUCT IS NO LONGER REQUIRED. REVIEW WILL BE CONDUCTED AT THE TIME OF PROJECT-SPECIFIC PLAN REVIEW.
- Bedding: Tanks must be placed on soils capable of bearing the weight of tank and its contents, when full. Soft soils or bedrock must have 3 inches of tamped material, sand or gravel, 100% of which passes ½-inch screen.

Grove Concrete & Supply Inc.  
November 16, 2016  
Page 2 of 2  
Product File No.: 20160285

- Backfill: Fill must contain no stones or debris larger than 3 inches in diameter. Place backfill in uniform layers no larger than 24 inches.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail