



December 19, 2016

SHERIDAN SEPTIC TANKS
VICTOR P. HELBACH
E627 SHERIDAN DR.
WAUPACA WI 54981

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: SHERIDAN SEPTIC TANKS
Product Name: (trans id 2798448) SEPTIC, HOLDING, PUMP OR SIPHON
Model Number(s): 750
(47.0 IN. L.L., 16.6 GAL/IN., 48 IN. MAX. DEPTH OF BURY, 374 G.P.D. WHEN USED AS
A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER; TANK DIMENSIONS (AVG.) = 45.5 IN. L X 48.88 IN. W X 49 IN. H)
Product File No: 20160300

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2021.

This approval supersedes the approval issued on November 7, 2011 under product file number 20110329.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Four-inch discharge opening in riser.
 - Two-inch schedule 40 PVC cast in riser for electrical wiring.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Four or six-inch inlet and outlet openings.
 - Press Seal "Cast-A-Seal" by Press Seal Gasket Corp.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD₅ greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- Backfill: Place backfill in uniform layers less than 24 inches thick. Backfill should be free of any large stones (greater than 3 inches in diameter) or other debris. [NPCA Best Practices]

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sheriden Septic Tanks
December 19, 2016
Page 2 of 2
Product File No.: 20160300

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail