



March 12, 2003

CULLIGAN INTERNATIONAL
BETH HUPP
2375 SANDERS RD.
NORTHBROOK IL 60062

Re: Description: WATER TREATMENT DEVICE-ACTIVATED CARBON
Manufacturer: CULLIGAN INTERNATIONAL
Product Name: GOLD COLLAR
Model Number(s): 9" AND 12"
Product File No: 20020381

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2008.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

**AESTHETIC CONTAMINANT REDUCTION CAPABILITIES
PRODUCT FILE NUMBER 20020381
TABLE 1 OF 1**

**Rated Service Flow Rates and Corresponding Pressure Losses,
liters per minute (lpm) @ pounds per square inch gauge (psig):**

9-inch Cullar = 15.1 lpm @ 2.0 psig [4.0 gallons per minute (gpm) @ 2.0 psig]
12-inch Cullar = 22.7 lpm @ 4.0 psig (6.0 gpm @ 4.0 psig)

Capacities, liters (l):

9-inch Cullar = 454,249 l [120,000 gallons (gals.)]
12-inch Cullar = 681,374 l (180,000 gals.)

Tested Contaminant	Influent Challenge (mg/l)*
Chlorine (free)	2.0 ± 10%

Other Conditions: the contaminant reduction performance capabilities displayed for Table 1 of 1 were verified by testing conducted in accordance with WQA Standard S-200-2000. To qualify for free chlorine reduction, the device must reduce the influent challenge concentrations by $\geq 75\%$.

* = milligrams per liter (mg/l) are equivalent to parts per million (ppm) \geq = greater than or equal to
mg/l = milligrams per liter \pm = plus or minus

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation that may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 **Phone**
(608) 267-9566 **Fax**
gschlueter@commerce.state.wi.us **Email**
8:00A - 4:30P CT **Work Hours**

GWS:gws