



October 15, 2003

MID-AMERICA WATER TREATMENT INC.
WILLIAM GUDEMAN
2015 W LAKE STREET
HANOVER PARK IL 60133

Re: Description: WATER TREATMENT DEVICE- SOFTENER
Manufacturer: MID-AMERICA WATER TREATMENT INC.
Product Name: AMBASSADOR
Model Number(s): 55-T-140, 55-MT-140, 55-T-210, 55-MT-210, 55-T-280, 55-MT-280, 55-T-350,
55-MT-350, 55-T-420, 55-MT-420, 55-CT-140, 55-MCT-140, 55-CT-280 AND
55-MCT-280
Product File No: 20030263

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2008.

This approval supercedes the approval issued on June 19, 1998 under product file number 19980082.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

**WATER SOFTENING CAPABILITIES
 PRODUCT FILE NUMBER 20030263
 TABLE 1 OF 1**

Model Numbers		Capacity*						Flow Rate vs. Pressure Loss
Ambassador Series		Rating 1		Rating 2		Rating 3		
Metered	Time Clock	Grains	Pounds	Grains	Pounds	Grains	Pounds	gpm @ psig
55-MT-140	55-MT-140	9,900	2.5	12,600	5.0	14,000	7.5	8.7 @ 15.0
55-MT-210	55-MT-210	14,900	3.8	18,100	7.5	21,000	11.3	7.9 @ 15.0
55-MT-280	55-MT-280	19,900	5.0	24,100	10.0	28,000	15.0	10.3 @ 15.0
55-MT-350	55-MT-350	24,800	6.3	31,400	12.5	35,000	18.8	9.3 @ 15.0
55-MT-420	55-MT-420	29,800	7.5	36,200	15.0	42,000	22.5	12.0 @ 15.0
55-MCT-140	55-MCT-140	9,900	2.5	12,600	5.0	14,000	7.5	8.7 @ 15.0
55-MCT-280	55-MCT-280	19,900	5.0	24,100	10.0	28,000	15.0	10.3 @ 15.0

* The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to verify the data for table 1 of 1 were conducted in accordance with WQA standard S-100-85. WQA S-100-85 has since been retired because the standard was harmonized and combined with NSF Standard 44.

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation that may result from its use.

Sincerely,

Glen W. Schlueter
 Engineering Consultant-Plumbing Product Reviewer
 Bureau of Integrated Services
 Safety and Buildings Division
 Department of Commerce
 (608) 267-1401 **Phone**
 (608) 267-9566 **Fax**
 gschlueter@commerce.state.wi.us **Email**
 8:00A - 4:30P CT **Work Hours**

GWS:gws