



December 2, 2003

HANSON WATER WORKS INCORPORATED  
PATRICK McCALLIGAN / TINA POLK  
PO BOX 206  
MENOMONEE FALLS WI 53051

Re: Description: WATER TREATMENT DEVICE- SOFTENER  
Manufacturer: HANSON WATER WORKS INCORPORATED  
Product Name: HANSON  
Model Number(s): H-1 5600, H-1 5600M, H-2 5600, H-2 5600M, H-2 5600SE, H-3 5600,  
H-3 5600M, H-3 5600SE, H-4 5600, H-4 5600M, H-4 5600SE, H-5 5600,  
H-5 5600M, H-5 5600SE, H-6 5600, H-6 5600M AND H-6 5600SE  
Product File No: 20030437

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2008.

This approval supercedes the approval issued on December 11, 1998 under product file number 19980487.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

**WATER SOFTENING CAPABILITIES  
 PRODUCT FILE NUMBER 20030437  
 TABLE 1 OF 1**

Model Numbers		Capacity*						Flow Rate vs.
5600 Series		Rating 1		Rating 2		Rating 3		Pressure Loss
Metered	Time Clock	Grains	Pounds	Grains	Pounds	Grains	Pounds	gpm @ psig
H-1 5600M	H-1 5600	8,600	2.7	12,200	4.5	16,700	7.5	6.1 @ 7.3
H-2 5600M	H-2 5600	13,000	4.1	18,300	6.8	25,700	11.3	8.4 @ 9.9
H-3 5600M	H-3 5600	17,300	5.5	24,500	9.1	33,400	15.0	10.0 @ 11.7
H-4 5600M	H-4 5600	25,900	8.2	36,700	13.6	50,000	22.5	9.7 @ 11.0
H-5 5600M	H-5 5600	34,500	10.9	48,900	18.2	66,700	30.0	12.0 @ 13.1
H-6 5600M	H-6 5600	51,800	16.4	73,400	27.3	100,100	45.0	12.0 @ 12.0
-	H-2 5600SE	13,000	4.1	18,300	6.8	25,700	11.3	8.4 @ 9.9
-	H-3 5600SE	17,300	5.5	24,500	9.1	33,400	15.0	10.0 @ 11.7
-	H-4 5600SE	25,900	8.2	36,700	13.6	50,000	22.5	9.7 @ 11.0
-	H-5 5600SE	34,500	10.9	48,900	18.2	66,700	30.0	12.0 @ 13.1
-	H-6 5600SE	51,800	16.4	73,400	27.3	100,100	45.0	12.0 @ 12.0

\* The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 were conducted in accordance with WQA Standard S-100-85. WQA Standard S-100-85 has since been retired and supplanted by NSF Standard 44.

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation that may result from its use.

Sincerely,

Glen W. Schlueter  
 Engineering Consultant-Plumbing Product Reviewer  
 Bureau of Integrated Services  
 Safety and Buildings Division  
 Department of Commerce  
 (608) 267-1401 **Phone**  
 (608) 267-9566 **Fax**  
 gschlueter@commerce.state.wi.us **Email**  
 8:00A - 4:30P CT **Work Hours**

GWS:gws