



March 31, 2004

GE OSMONICS  
RANDY BURIAN  
5730 N GLEN PARK ROAD  
MILWAUKEE WI 53209

Re: Description: WATER TREATMENT CHEMICAL INJECTION DEVICE  
Manufacturer: GE OSMONICS  
Product Name: LAND-O-MATIC  
Model Number(s): LP-3000 SERIES  
Product File No: 20040114

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2009.

This approval supercedes the approval issued on June 16, 1999 under product file number 19990310.

This approval is contingent upon compliance with the following stipulation(s):

- Only Land Products Dry Chlorine Pellets, Environmental Protection Agency Registration number 50510-1, weighing one gram, may be used with this product.
- This product has undergone sufficient testing to document the product's ability to properly inject a chemical into a water supply system as specified in this approval letter.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product to inject a chemical into a water supply system. For more information contact the DNR Private Water Systems Section , P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation that may result from its use.

Sincerely,

Glen W. Schlueter  
Engineering Consultant-Plumbing Product Reviewer  
Bureau of Integrated Services  
Safety and Buildings Division  
Department of Commerce  
(608) 267-1401 **Phone**  
(608) 267-9566 **Fax**  
gschlueter@commerce.state.wi.us **Email**  
8:00A - 4:00P CT **Work Hours**

GWS:gws