



April 1, 2004

CUSTOM CARE WATER TECHNOLOGIES INC.
DANIEL M. PETERS
9087 WESTPHAL LANE
NEENAH WI 54956

Re: Description: WATER TREATMENT DEVICE- SOFTENER
Manufacturer: CUSTOM CARE WATER TECHNOLOGIES INC.
Product Name: CUSTOMSOFT SERIES 1100
Model Number(s): 1111,1121,1131,1151,1161, 1112,1122,1132,1152,1162
1113,1123,1133,1153,1163, 1114,1124,1134,1154 AND 1164
Product File No: 20040121

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

**WATER SOFTENING CAPABILITIES
 PRODUCT FILE NUMBER 20040121
 TABLE 1 OF 1**

Model Numbers		Capacities*						Flow Rate vs.
CustomSoft Series 1100		Rating 1		Rating 2		Rating 3		Pressure Loss
Metered	Time Clock	Grains	Pounds	Grains	Pounds	Grains	Pounds	gpm @ psig
1112	1111	9,600	2.5	13,500	5.0	15,300	7.0	4.0 @ 5.0
1122	1121	15,500	3.8	21,700	7.5	24,600	10.5	6.0 @ 9.0
1132	1131	20,700	5.0	29,000	10.0	32,800	14.0	5.7 @ 6.0
1152	1151	31,000	7.5	43,500	15.0	49,100	21.0	9.6 @ 15.0
1162	1161	41,400	10.0	58,000	20.0	65,500	28.0	11.2 @ 15.0
1113	-	9,600	2.5	13,500	5.0	15,300	7.0	4.0 @ 5.0
1123	-	15,500	3.8	21,700	7.5	24,600	10.5	6.0 @ 9.0
1133	-	20,700	5.0	29,000	10.0	32,800	14.0	5.7 @ 6.0
1153	-	31,000	7.5	43,500	15.0	49,100	21.0	9.6 @ 15.0
1163	-	41,400	10.0	58,000	20.0	65,500	28.0	11.2 @ 15.0
1114	-	9,600	2.5	13,500	5.0	15,300	7.0	4.0 @ 5.0
1124	-	15,500	3.8	21,700	7.5	24,600	10.5	6.0 @ 9.0
1134	-	20,700	5.0	29,000	10.0	32,800	14.0	5.7 @ 6.0
1154	-	31,000	7.5	43,500	15.0	49,100	21.0	9.6 @ 15.0
1164	-	41,400	10.0	58,000	20.0	65,500	28.0	11.2 @ 15.0

* The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 were conducted in accordance with NSF Standard 44.

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation that may result from its use.

Sincerely,

Glen W. Schlueter
 Engineering Consultant-Plumbing Product Reviewer
 Bureau of Integrated Services
 Safety and Buildings Division
 Department of Commerce
 (608) 267-1401 **Phone**
 (608) 267-9566 **Fax**
 gschlueter@commerce.state.wi.us **Email**
 8:00A - 4:30P CT **Work Hours**

GWS:gws