



September 22, 2004

DIAMOND WATER CONDITIONING
RUSS PARKER
N1022 QUALITY DR
PO BOX 170
GREENVILLE WI 54942

Re: Description: WATER TREATMENT DEVICE-ACTIVATED CARBON
Manufacturer: DIAMOND WATER CONDITIONING
Product Name: PPSC SERIES
Model Number(s): PPSC-100A, PPSC-150A AND PPSC-200A
Product File No: 20040447

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2009.

This approval supercedes the approval issued on July 23, 1999 under product file number 19990405.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

**AESTHETIC CONTAMINANT REDUCTION CAPABILITIES
PRODUCT FILE NUMBER 20040447
TABLE 1 OF 1**

Flow Rates and Corresponding Pressure Losses:

PPSC-100A = 18.9 liters per minute (lpm) @ 23.4 kilopascals (kPa) [5.0 gallons per minute (gpm) @ 3.4 pounds per square inch gauge (psig)]
PPSC-150A = 18.9 lpm @ 24.1 kPa (5.0 gpm @ 3.5 psig)
PPSC-200A = 22.7 lpm @ 26.9 kPa (6.0 gpm @ 3.9 psig)

Capacities:

PPSC-100A = 344,128 liters (l) [90,909 gallons (gals.)]
PPSC-150A = 516,194 l (136,364 gals.)
PPSC-200A = 688,256 l (181,818 gals.)

Tested Contaminant	Average Influent Challenge (mg/l) ¹
Chlorine (free)	11.0

Other Conditions: the contaminant reduction performance capabilities displayed for Table 1 of 1 were verified by testing conducted by Baumbach Labs, Appleton WI in accordance with WQA Standard S-200-73. To qualify for free chlorine reduction, the device must reduce the influent challenge concentrations such that all effluent concentrations are \leq 0.1 mg/l. Note, the influent challenge concentration required under S-200-73 is 3.0 mg/l, Baumbach Labs elected to run the test at a higher influent challenge concentration.

¹ = milligrams per liter (mg/l) are equivalent to parts per million (ppm)
 \pm = plus or minus
 \leq = less than or equal to

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation that may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 **Phone**
(608) 267-9566 **Fax**
gschlueter@commerce.state.wi.us **Email**
8:00AM – 4:30PM CDT **Work Hours**

GWS:gws