



Jim Doyle, Governor
Cory L. Nettles, Secretary

September 28, 2004

BETTER WATER INDUSTRIES INC
TATE BURCKHARDT
209 N TYLER ST
PO BOX G
TYLER MN 56178

BETTER WATER INDUSTRIES, INC.
LENNIE BURCKHARDT
209 NORTH TYLER STREET
PO BOX G
TYLER MN 56178

Re: Description: WATER TREATMENT CHEMICAL INJECTION DEVICE
Manufacturer: BETTER WATER INDUSTRIES, INC.
Product Name: SENTRY I DRY PELLET CHLORINATOR
Model Number(s): SIC 110, SIC 220, RS120004 (M)(R),
RS120006 (M)(R) AND RS120015 (M)(R)
Product File No: 20040477

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2009.

This approval is contingent upon compliance with the following stipulation(s):

- Only dry calcium hypochlorite pellets, Environmental Protection Agency Registration number 50510-1, weighing 0.8 gram, with a minimum of 70% free available chlorine, may be used with this product.
- This product has undergone sufficient testing to document the product's ability to properly inject a chemical into a water supply system as specified in this approval letter.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product to inject a chemical into a water supply system. For more information contact the DNR Private Water Systems Section, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation that may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 **Phone**
(608) 267-9566 **Fax**
gschlueter@commerce.state.wi.us **Email**
8:00AM – 4:30PM CDT **Work Hours**
GWS:gws
SBD-10564-E (N.10/97)