



Jim Doyle, Governor
Mary P. Burke, Secretary

June 6, 2005

EVERPURE INCORPORATED
ANN SCHLEINZ
502 INDIANA AV
SHEBOYGAN WI 53081

Re: Description: WATER TREATMENT DEVICE-ACTIVATED CARBON
Manufacturer: EVERPURE INCORPORATED
Product Name: EVERPURE
Model Number(s): H-104 USING THE H-104 CARTRIDGE
Product File No: 20050209

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2008.

This approval supercedes the approval issued on September 3, 2003 under product file number 20030317.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If this approved device is modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These devices will only reduce the concentration of cysts/oocysts at water outlets that are served by the devices. Therefore, using point-of-use devices such as these will not protect all routes of potential exposure. Potentially hazardous exposures to cysts/oocysts will remain possible at unprotected outlets.

The presence of cysts/oocysts strongly suggests that other pathogens (e.g. bacteria, virus) may also be present.

If, by way of reputable water analyses, a water supply is known to contain cysts/oocysts, then all the water entering the residence must be treated at the point-of-entry, using an approved water treatment device, to address all potential routes of exposure thereby providing a biologically safe water supply.

Based on testing data submitted to and reviewed by the department, this approval recognizes that this plumbing product will reduce the concentration of contaminants as specified on pages 1 through 3 of this letter.

AESTHETIC CONTAMINANT REDUCTION CAPABILITIES
PRODUCT FILE NUMBER 20050209
TABLE 1 OF 3

Flow Rate: 1.9 liters per minute (lpm) [0.5 gallon per minute (gpm)]
Capacity: 3,785 liters (l) [1,000 gallons (gals.)] for the reduction of free chlorine. For particulate reduction, dependent on the type and quantity of particulate matter present in the influent water; the need for maintenance may be indicated by a significant decrease in flow rate.

| Tested Contaminant | Influent Challenge (mg/l)*, 1 |
|--------------------------------|-------------------------------|
| Chlorine (free) | 2.0 ± 10% |
| Particulates (0.5 to < 1.0 µm) | 1.0 x 10 ⁴ #/ml |

Other Conditions: the contaminant reduction performance capabilities displayed for Table 1 of 3 were verified by testing conducted in accordance with NSF *International* Standard 42. To qualify for free chlorine reduction, the device must reduce the influent challenge concentrations by ≥ 50%; meeting the free chlorine reduction requirements also qualifies the device for the reduction of aesthetic, organic, taste and odor reduction (e.g. geosmin, methylisoborneol); this does not include hydrogen sulfide. To qualify for particulate reduction (Class I) the device must reduce the influent challenge concentrations by ≥ 85%.

1 = mg/l are equivalent to parts per million (ppm)

< = less than

≥ = greater than or equal to

µm = micrometers

* = unless otherwise specified

#/ml = particles per milliliter

± = plus or minus

HEALTH EFFECTING BIOLOGICAL CONTAMINANT REDUCTION CAPABILITIES
PRODUCT FILE NUMBER 20050209
TABLE 2 OF 3

Flow Rate: 1.9 lpm (0.5 gpm)
Capacity: dependent on the type and quantity of particulate matter present in the influent water; the need for maintenance may be indicated by a significant decrease in flow rate.

| Tested Contaminant | Influent Challenge (#/ml) |
|----------------------------|---------------------------|
| Cysts/Oocysts ¹ | ≥ 5.0 x 10 ⁴ |

Other Conditions: the contaminant reduction performance capabilities displayed for Table 2 of 3 were verified by testing conducted in accordance with NSF *International* Standard 53. To qualify for cyst/oocyst reduction, the device must reduce the influent challenge concentrations by ≥ 99.95% at each sample point.

1 = the specific organisms covered under this testing protocol include cryptosporidium parvum, entamoeba histolytica, giardia lamblia and toxoplasma gondii

#/ml = particles per milliliter

≥ = greater than or equal to

**HEALTH EFFECTING INORGANIC CONTAMINANT REDUCTION CAPABILITIES
PRODUCT FILE NUMBER 20050209
TABLE 3 OF 3**

Flow Rate: 1.9 lpm (0.5 gpm)
Capacity: 3,785 l (1,000 gals.) for lead reduction. For asbestos reduction, the capacity is dependent on the type and quantity of particulate matter present in the influent water; the need for maintenance may be indicated by a significant decrease in flow rate.

| Tested Contaminant | Influent Challenge Concentration (mg/l) ¹ |
|--|--|
| Asbestos Fibers (> 10 μ m in length) | 1.0 x 10 ⁷ to 1.0 x 10 ⁸ F/l |
| Lead (Pb ⁺²) ² | 0.15 \pm 10% |

Other Conditions: the contaminant reduction performance capabilities displayed for Table 3 of 3 were verified by testing conducted in accordance with NSF *International* Standard 53. To qualify for asbestos reduction, the device must reduce the influent challenge concentrations by \geq 99%. To qualify for lead reduction, the device must reduce the influent challenge concentrations such that all effluent concentrations are \leq 0.010 mg/l.

1 = milligrams per liter (mg/l) are equivalent to parts per million (ppm)

2 = metals are tested at pH 6.5 and pH 8.5

F/l = fibers per liter

* = unless otherwise specified

\leq = less than or equal to

\geq = greater than or equal to

\pm = plus or minus

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation that may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 **Phone**
(608) 267-9566 **Fax**
gschlueter@commerce.state.wi.us **Email**
8:00A – 4:30P CDT **Work Hours**

GWS:gws