

November 6, 2006

WATER GROUP COMPANIES INC  
JASON KAROL  
580 PARK ST  
SASKATCHEWAN S4N 5Z6  
CANADA

WATER GROUP INC  
GEOFF BROWN  
193 OSBORN RD  
FRIDLEY MN 55432

Re: Description: WATER TREATMENT DEVICE- SOFTENER  
Manufacturer: WATER GROUP INC  
Product Name: HYDROTECH 7000 WI WATER SOFTENERS  
Model Number(s): WI7000-100, WI7000-125, WI7000-150, WI7000-200 AND WI7000-300  
Product File No: 20060033

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2011.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

**WATER SOFTENING CAPABILITIES  
 PRODUCT FILE NUMBER 20060033  
 TABLE 1 OF 1**

Model Numbers Hydrotech Series	Capacity*						Flow Rate vs. Pressure Loss gpm @ psig
	Rating 1		Rating 2		Rating 3		
Metered	Grains	Pounds	Grains	Pounds	Grains	Pounds	
WI7000-1.0	17,280	4.0	29,518	9.0	33,352	15.0	11.5 @ 9.4
WI7000-1.25	22,444	5.0	38,339	11.3	43,319	18.8	12.0 @ 8.5
WI7000-1.5	26,933	6.0	46,007	13.5	51,983	22.5	15.6 @ 15.0
WI7000-2.0	35,911	8.0	61,343	18.0	69,311	30.0	19.2 @ 15.0
WI7000-3.0	53,866	12.0	92,014	27.0	103,966	45.0	19.9 @ 15.0

\* The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 were conducted in accordance with NSF Standard 44 .

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
 Engineering Consultant-Plumbing Product Reviewer  
 Bureau of Integrated Services  
 Safety and Buildings Division  
 Department of Commerce  
 (608) 267-1401 **Phone**  
 (608) 267-9566 **Fax**  
 gschlueter@commerce.state.wi.us **Email**  
 8:00AM – 4:30PM CT **Work Hours**

GWS:gws