



Jim Doyle, Governor
Mary P. Burke, Secretary

July 14, 2006

CULLIGAN INTERNATIONAL
RESEARCH AND DEVELOPMENT
ANNA K. LEVOY
ONE CULLIGAN PKWY
NORTHBROOK IL 60062-6209

PENTAIR
PLYMOUTH PRODUCTS
ANNE SCHLEINZ
502 INDIANA AVE.
SHEBOYGAN WI 53081

Re: Description: WATER TREATMENT DEVICE-ACTIVATED CARBON
Manufacturer: PENTAIR
Product Name: EASY CHANGE UNDER-SINK AND WATER DISPENSER/ICE FILTER SYSTEMS
Model Number(s): IC-1000, SY-1000 AND SY-1000S ALL USING THE 1000R CARTRIDGE
Product File No: 20060118

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2011.

This approval supersedes the approval issued on July 1, 2003 under product file number 20030176.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These devices will only reduce the concentration of volatile organic chemicals at water outlets that are served by the devices. There are dermal (skin) absorption and inhalation exposure risks associated with volatile organic chemicals. Therefore, using point-of-use devices such as these will not protect all routes of potential exposure. Potentially hazardous exposures to volatile organic chemicals will remain possible at unprotected outlets, particularly hot water outlets (e.g. bathing, showering, clothes washing or dish washing).

If, by way of reputable water analyses, a water supply is known to contain unsafe levels of volatile organic chemicals, then all the water entering the residence must be treated at the point-of-entry using an approved water treatment device to address all potential routes of exposure.

- These devices will only reduce the concentration of cysts/oocysts at water outlets that are served by the devices. Therefore, using point-of-use devices such as these will not protect all routes of potential exposure. Potentially hazardous exposures to cysts/oocysts will remain possible at unprotected outlets.

The presence of cysts/oocysts strongly suggests that other pathogens (e.g. bacteria, virus) may also be present.

If, by way of reputable water analyses, a water supply is known to contain cysts/oocysts, then all the water entering the residence must be treated at the point-of-entry, using an approved water treatment device, to address all potential routes of exposure thereby providing a biologically safe water supply.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 4 of this letter.

HEALTH EFFECTING ORGANIC CONTAMINANT REDUCTION CAPABILITIES
PRODUCT FILE NUMBER 20060118
TABLE 1 OF 4

Flow Rate: 1.9 liters per minute (lpm) [0.5 gallon per minute (gpm)]
Capacity: 1,893 liters (l) [500 gallons (gals.)]

Tested Contaminant	Influent Challenge ($\mu\text{g/l}$) ¹
Atrazine	9.0 \pm 10%
Lindane	0.6 \pm 10%

Other Conditions: the contaminant reduction performance capabilities displayed for Table 1 of 4 were verified by testing conducted in accordance with NSF *International* Standard 53. To qualify for atrazine reduction, the device must reduce the influent challenge concentrations such that all effluent concentrations are \leq 3.0 $\mu\text{g/l}$. To qualify for lindane reduction, the device must reduce the influent challenge concentrations such that all effluent concentrations are \leq 0.2 $\mu\text{g/l}$.

¹ = micrograms per liter ($\mu\text{g/l}$) are equivalent to parts per billion (ppb)
 \leq = less than or equal to
 \pm = plus or minus

HEALTH EFFECTING INORGANIC CONTAMINANT REDUCTION CAPABILITIES
PRODUCT FILE NUMBER 20060118
TABLE 2 OF 4

Flow Rate: 1.9 lpm (0.5 gpm)
Capacity: 1,893 l (500 gals.)

Tested Contaminant	Influent Challenge Concentration (mg/l) ¹
Lead (Pb^{+2}) ²	0.15 \pm 10%

Other Conditions: the contaminant reduction performance capabilities displayed for Table 2 of 4 were verified by testing conducted in accordance with NSF *International* Standard 53. To qualify for lead reduction, the device must reduce the influent challenge concentrations such that all effluent concentrations are \leq 0.010 mg/l.

¹ = milligrams per liter (mg/l) are equivalent to parts per million (ppm)
² = metals are tested at pH 6.5 and pH 8.5
 \leq = less than or equal to
 \pm = plus or minus

**HEALTH EFFECTING BIOLOGICAL CONTAMINANT REDUCTION CAPABILITIES
 PRODUCT FILE NUMBER 20060118**

TABLE 3 OF 4

Flow Rate: 1.9 lpm (0.5 gpm)
Capacity: dependent on the type and quantity of particulate matter present in the influent water; the need for maintenance may be indicated by a significant decrease in flow rate.

Tested Contaminant	Influent Challenge (#/ml)
Cysts/Oocysts ¹	≥ 5.0 x 10 ⁴

Other Conditions: the contaminant reduction performance capabilities displayed for Table 3 of 4 were verified by testing conducted in accordance with NSF *International* Standard 53. To qualify for cyst/oocyst reduction, the device must reduce the influent challenge concentrations by ≥ 99.95% at each sample point.

¹ = the specific organisms covered under this testing protocol include cryptosporidium parvum, entamoeba histolytica, giardia lamblia and toxoplasma gondii

≥ = greater than or equal to

#/ml = particles per milliliter

**AESTHETIC CONTAMINANT REDUCTION CAPABILITIES
 PRODUCT FILE NUMBER 20060118**

TABLE 4 OF 4

Flow Rate: 1.9 lpm (0.5 gpm)
Capacity: 1,893 l (500 gals.) for free chlorine reduction. For particulate reduction, the capacity is dependent on the type and quantity of particulate matter present in the influent water; the need for maintenance may be indicated by a significant decrease in flow rate.

Tested Contaminant	Influent Challenge (mg/l) ^{*, 1}
Chlorine (free)	2.0 ± 10%
Particulates (0.5 to < 1.0 μm)	1.0 x 10 ⁴ #/ml

Other Conditions: the contaminant reduction performance capabilities displayed for Table 4 of 4 were verified by testing conducted in accordance with NSF *International* Standard 42. To qualify for free chlorine reduction, the device must reduce the influent challenge concentrations by ≥ 50%. To qualify for particulate reduction (Class 1), the device must reduce the influent challenge concentrations by ≥ 85%.

¹ = milligrams per liter (mg/l) are equivalent to parts per million (ppm)

* = unless otherwise specified

< = less than

μm = micrometers

#/ml = particles per milliliter

≥ = greater than or equal to

± = plus or minus

Culligan International
July 14, 2006
Page 4 of 4
Product File No.: 20060118

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation that may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 **Phone**
(608) 267-9566 **Fax**
gschlueter@commerce.state.wi.us **Email**
8:00A - 4:30P CDT **Work Hours**

GWS:gws