



March 21, 2012

REVISED COPY

WATER QUALITY ASSOCIATION
MELISSA STANLEY
4151 NAPERVILLE ROAD
LISLE IL 60532

ENAGIC USA
LINDA CHOI
4115 SPENCER STREET
TORRENCE CA 90503

Re: Description: WATER TREATMENT DEVICE - POU ACTIVATED CARBON
Manufacturer: ENAGIC USA
Product Name: LEVELLUK SD 501
Model Number(s): TYH-401
Product File No: 20120110

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2017.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- The free chlorine and particulate reduction capabilities approved for this device are based entirely on the attributes of the activated carbon filter (i.e. HG-N). This approval does not approve or acknowledge the electrolytic aspects of this device or any claims associated with pH modification.
- The scope of this approval is limited to treated water produced by this device in a pH range of 6.5 - 8.5. This is the secondary maximum contaminant level (SMCL) for pH suggested for potable water by the U.S. Environmental Protection Agency (USEPA) under the Safe Drinking Water Act (SDWA).

This approval does not, in any way, acknowledge, endorse nor support:

1. using water outside of the pH 6.5 - 8.5 range;
2. any benefits, particularly health benefits, the manufacturer may claim for using and/or consuming water outside of the pH 6.5 - 8.5 range (e.g. "Kangen Water", "Strong Kangen Water", "Acidic Water" and "Strong Electrolytic Water").
3. the notion that consuming water with an alkaline pH has any inherent health benefits whatsoever in excess of simple hydration.

- This device is approved for the reduction of free chlorine and particulates only; these two claims are supported by reproducible scientific evidence.

No other performance claims of any type are supported by this approval.

- The electric service to this device shall be via a ground fault circuit interrupter (GFCI) receptacle.
- It is important for consumers to realize the manufacturer's warranty for this device does not apply if this device is installed on private water supplies (i.e. private wells).
- If this approved device is modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- If the treatment components of this device (e.g., replacement cartridge) are replaced with anything other than those originally approved for use with this device, then this approval shall immediately be considered null and void.

Based on testing data submitted to and reviewed by the department, this approval recognizes that this plumbing product will reduce the concentration of contaminants as specified on pages 1 through 3 of this letter.

AESTHETIC CONTAMINANT REDUCTION CAPABILITIES
PRODUCT FILE NUMBER 20120110
TABLE 1 OF 1

Flow Rate: 4.2 liters per minute (lpm) [1.1 gallon per minute (gpm)]
Capacity: 5,678 liters (l) (1,500 gals.) for free chlorine reduction. For particulate reduction the capacity is dependent on the type and quantity of particulate matter present in the untreated water; the need for maintenance may be indicated by a significant decrease in flow rate.

Tested Contaminant	Influent Challenge (mg/l)** 1
Chlorine (free)	2.0 ± 10%
Particulates (≥ 5.0 to < 15.0 µm)	≥ 1.0 x 10 ⁴ #/ml

Other Conditions: the contaminant reduction performance capabilities displayed for Table 1 of 1 were verified by testing conducted in accordance with NSF *International* Standard 42 by the Water Quality Association, Lisle IL. To qualify for free chlorine reduction, the device must reduce the influent challenge concentrations by ≥ 50%; meeting the free chlorine reduction requirements also qualifies the device for the reduction of aesthetic, organic, taste and odor reduction (e.g. geosmin, methylisoborneol); this does not include hydrogen sulfide. To qualify for particulate reduction (Class III) the device must reduce the influent challenge concentrations by ≥ 85%.

The free chlorine and particulate reduction capabilities approved for this device are based entirely on the attributes of the activated carbon filter (i.e. HG-N). This approval does not approve or acknowledge the electrolytic aspects of this device or any claims associated with pH modification.

1 = milligrams per liter (mg/l) are equivalent to parts per million (ppm)
 ≥ = greater than or equal to
 ± = plus or minus
 #/ml = particles per milliliter

< = less than
 µm = micrometers
 * = unless otherwise specified

Enagic USA
March 21, 2012
Page 3 of 3
Product File No.: 20120110

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely

,Glen W. Schluter
Engineering Consultant
Safety and Buildings Division
Department of Safety and Professional Services
(608) 267-1401 **Phone**
(608) 267-9566 **Fax**
glen.schluter@wi.gov **Email**
7:30AM - 4:30PM CT **Work Hours**
GWS:gws