



April 26, 2013

AQUION INCORPORATED
BIBHA DAHAL
101 S. GARY AVENUE
ROSELLE IL 60172

Re: Description: WATER TREATMENT DEVICE - POE OXIDIZING
Manufacturer: AQUION INCORPORATED
Product Name: RAINSOFT RFC OXYTECH SERIES
Model Number(s): EC4 OXYTECH 150 MM, EC4 OXYTECH 150 PLUS MM AND EC4 OXYTECH 250 MM
Product File No: 20130115

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2018.

This approval supersedes the approval issued on July 29, 2008 under product file number 20070339.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- Operation of this/these device(s) and flow rates above the rated service flow rates indicated within this approval letter are not supported or acknowledged by this approval. The rated service flow rate(s) is/are the flow rate(s) at which this/these device(s) were tested.

Because the level of treatment obtained is a function of how long the water is in contact with the treatment media within this/these device(s), arbitrary increases in the flow rate(s), above the rated service flow rate(s) may compromise the quality of the treated water.

- These devices are not approved for the reduction of hydrogen sulfide.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

**AESTHETIC CONTAMINANT REDUCTION CAPABILITIES
PRODUCT FILE NUMBER 20130115
TABLE 1 OF 1**

Flow Rates: EC4 Oxytech 150MM = 5.0 gallons per minute (gpm) [18.9 liters per minute (lpm)]
EC4 Oxytech 150 Plus MM = 6.0 gpm (22.7 lpm)
EC4 Oxytech 250MM = 7.0 gpm (26.5 lpm)

Capacities: EC4 Oxytech 150MM = 700 gallons (gals.) [2,650 liters (l)]:
EC4 Oxytech 150 Plus MM = 700 gals. (2,650 l)
EC4 Oxytech 250MM = 1,150 gals. (4,353 l)

Tested Contaminant	Avg. Influent Challenge (mg/l) ¹
Iron	3.7
Manganese	1.7

Other Conditions: the contaminant reduction performance capabilities displayed for Table 1 of 1 were verified by testing conducted in accordance with WQA Standard S-200. To qualify for dissolved iron reduction, the device must reduce the influent challenge concentrations such that all effluent concentrations are ≤ 0.3 mg/l. To qualify for manganese reduction, the device must reduce the influent challenge concentrations such that all effluent concentrations are ≤ 0.05 mg/l.

¹ = milligrams per liter (mg/l) are equivalent to parts per million (ppm)
 \geq = greater than or equal to

\leq = less than or equal to
 \pm = plus or minus

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 266-2602 Fax
glen.schlueter@wi.gov E-mail