



July 22, 2013

WATER QUALITY ASSOCIATION
KYLE WHALEN
4151 NAPERVILLE ROAD
LISLE IL 60532

BRONDELL INCORPORATED
STEVE SCHEER
2183 SUTTER STREET
SAN FRANCISCO CA 94115

Re: Description: WATER TREATMENT DEVICE - ACTIVATED CARBON
Manufacturer: BRONDELL INCORPORATED
Product Name: CYPRESS
Model Number(s): H630 USING THE HF-31, HF-32 AND HF-33 CARTRIDGES
Product File No: 20130127

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2018.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If this approved device is modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These devices will only reduce the concentration of volatile organic chemicals at water outlets that are served by the devices. There are dermal (skin) absorption and inhalation exposure risks associated with volatile organic chemicals. Therefore, using point-of-use devices such as these will not protect all routes of potential exposure. Potentially hazardous exposures to volatile organic chemicals will remain possible at unprotected outlets, particularly hot water outlets (e.g. bathing, showering, clothes washing or dish washing).

If, by way of reputable water analyses, a water supply is known to contain unsafe levels of volatile organic chemicals, then all the water entering the residence must be treated at the point-of-entry using an approved water treatment device to address all potential routes of exposure.

- If the treatment components of this device (e.g., replacement cartridge) are replaced with anything other than those originally approved for use with this device, then this approval shall immediately be considered null and void.

Based on testing data submitted to and reviewed by the department, this approval recognizes that this plumbing product will reduce the concentration of contaminants as specified on pages 1 through 3 of this letter.

**AESTHETIC CONTAMINANT REDUCTION CAPABILITIES
 PRODUCT FILE NUMBER 20130127
 TABLE 1 OF 2**

Flow Rate: 1.9 liters per minute (lpm) [0.5 gallon per minute (gpm)]
Capacity: 18,927 liters (l) [5,000 gallons (gals.)] for free chlorine reduction. For particulate reduction, the capacity is dependent on the type and quantity of particulate matter present in the untreated water; the need for maintenance may be indicated by a significant decrease in flow rate.

Tested Contaminant	Influent Challenge (mg/l)*, 1
Chlorine (free)	2.0 ± 10%
Particulates (0.5 to < 1.0 µm)	≥ 1.0 x 10 ⁴ #/ml

Other Conditions: the contaminant reduction performance capabilities displayed for Table 1 of 2 were verified by testing conducted in accordance with NSF *International* Standard 42. To qualify for free chlorine reduction, the device must reduce the influent challenge concentrations by ≥ 50%. To qualify for particulate reduction, Class I, the device must reduce the influent challenge concentrations by ≥ 85%.

1 = milligrams per liter (mg/l) are equivalent to parts per million (ppm)
 #/ml = particles per milliliter
 ≥ = greater than or equal to
 ± = plus or minus

* = unless otherwise specified
 < = less than
 µm = micrometers

**HEALTH EFFECTING ORGANIC CONTAMINANT REDUCTION CAPABILITIES
 (VIA CHLOROFORM SURROGATE)
 PRODUCT FILE NUMBER 20130127
 TABLE 2 OF 2**

Flow Rate: 1.9 lpm (0.5 gpm)
Capacity: 4,997 l (90 gals.)

Tested Contaminant	Influent Challenge (µg/l) ¹
Alachlor	50
Atrazine	100
Benzene	81
Carbofuran	190
Carbon tetrachloride	78
Chlorobenzene	77
Chloropicrin	15
2,4-D	110
Dibromochloropropane (DBCP)	52
o-Dichlorobenzene	80
p-Dichlorobenzene	40
1,2-Dichloroethane	88
1,1-Dichloroethylene	83
cis-1,2-Dichloroethylene	170
trans-1,2-Dichloroethylene	86
1,2-Dichloropropane	80
cis-1,3-Dichloropropylene	79
Dinoseb	170
Endrin	53
Ethylbenzene	88
Ethylene dibromide (EDB)	44
Haloacetonitriles (HAN):	-
Bromochloroacetonitrile	22
Dibromoacetonitrile	24
Dichloroacetonitrile	9.6
Trichloroacetonitrile	15
Haloketones (HK):	-
1,1-Dichloro-2-propanone	7.2
1,1,1-Trichloro-2-propanone	8.2

(continued from previous page)

Heptachlor	25
Heptachlor epoxide	10.7
Hexachlorobutadiene	44
Hexachlorocyclopentadiene	60
Lindane	55
Methoxychlor	50
Pentachlorophenol	96
Simazine	120
Styrene	150
1,1,2,2-Tetrachloroethane	81
Tetrachloroethylene	81
Toluene	78
2,4,5-TP (silvex)	270
Tribromoacetic acid	42
1,2,4-Trichlorobenzene	160
1,1,1-Trichloroethane	84
1,1,2-Trichloroethane	150
Trichloroethylene	180
Trihalomethanes (chloroform surrogate)	300
Xylenes (total)	70

Other Conditions: the contaminant reduction performance capabilities displayed for Table 2 of 2 were verified by testing conducted in accordance with NSF *International* Standard 53. To qualify for the reduction of the organic contaminants listed above, the device must reduce the influent challenge concentration of chloroform at 300 µg/l ± 10% at each sample point by ≥ 95%.

1 = micrograms per liter (µg/l) are equivalent to parts per billion (ppb)

≥ = greater than or equal to

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail