



May 20, 2015

MARLO INCORPORATED  
SUSAN ERICKSON  
2227 SOUTH ST.  
PO BOX 044170  
RACINE WI 53404-7003

Re: Description: WATER TREATMENT DEVICE - SOFTENER/CATION EXCHANGE  
Manufacturer: MARLO INCORPORATED  
Product Name: MARLO INCORPORATED "A" SERIES WATER SOFTENERS (POE)  
Model Number(s): A-22, A-30, A-45 AND A-60  
Product File No: 20150057

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2020.

This approval supersedes the approval issued on June 22, 2010 under product file number 20100226.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

**WATER SOFTENING CAPABILITIES  
 PRODUCT FILE NUMBER 20150057  
 TABLE 1 OF 1**

Model Numbers	Capacity						Maximum Rated Service Flow Rate
	Rating 1		Rating 2		Rating 3		
Metered	Grains	Pounds	Grains	Pounds	Grains	Pounds	gpm @ psig
Marlo A-Series							
A15-2-STD	9,600	2.5	12,400	5.0	14,800	7.5	7.0 @ 15.0
A15-C-STD	9,600	2.5	12,400	5.0	14,800	7.5	7.0 @ 15.0
A15-2-TUR	9,600	2.5	12,400	5.0	14,800	7.5	7.0 @ 15.0
A15-2-TUR	9,600	2.5	12,400	5.0	14,800	7.5	7.0 @ 15.0
A22-2-STD	14,500	3.8	18,500	7.5	22,200	11.3	8.2 @ 15.0
A22-C-STD	14,500	3.8	18,500	7.5	22,200	11.3	8.2 @ 15.0
A22-2-TUR	14,500	3.8	18,500	7.5	22,200	11.3	8.2 @ 15.0
A22-C-TUR	14,500	3.8	18,500	7.5	22,200	11.3	8.2 @ 15.0
A30-2-STD	19,300	5.0	24,700	10.0	29,600	15.0	9.0 @ 15.0
A30-C-STD	19,300	5.0	24,700	10.0	29,600	15.0	9.0 @ 15.0
A30-2-TUR	19,300	5.0	24,700	10.0	29,600	15.0	9.0 @ 15.0
A30-C-TUR	19,300	5.0	24,700	10.0	29,600	15.0	9.0 @ 15.0
A40-2-STD	25,100	6.6	32,100	13.0	38,500	19.6	8.0 @ 15.0
A40-2-TUR	25,100	6.6	32,100	13.0	38,500	19.6	8.0 @ 15.0
A45-2-STD	28,900	7.6	37,100	15.0	44,400	22.6	9.0 @ 15.0
A45-2-TUR	28,900	7.6	37,100	15.0	44,400	22.6	9.0 @ 15.0
A60-2-STD	38,600	10.0	49,400	20.0	59,200	30.1	10.3 @ 15.0
A60-2-TUR	38,600	10.0	49,400	20.0	59,200	30.1	10.3 @ 15.0

\* The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 were conducted in accordance with NSF Standard 44.

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
 Environmental Engineer - Plumbing Product Reviewer  
 Department of Safety and Professional Services  
 Division of Industry Services  
 Bureau of Technical Services  
 (608) 267-1401 Phone  
 (608) 267-9723 Fax  
 glen.schlueter@wi.gov E-mail