



Cross Connection Control Performance Test

All cross connection control device registrations must be completed via the Department's eSLA system at: <http://esla.wi.gov>
 Personal information you provide may be used for secondary purposes [Privacy Law, s.1504 (1)(m)].

DIS Object Number: _____

Owner Information

Owner Name			Street Address		
City	State	Zip Code	Owner's Contact Person		Telephone Number

Facility Information

Facility Name			Street Address		
City	Zip Code		County		
Assembly Location			Assembly is Serving		
Manufacturer			Model		Serial Number
Size _____	Assembly Type	<input type="checkbox"/> RP	<input type="checkbox"/> RP Detector	<input type="checkbox"/> PVB	<input type="checkbox"/> SRVB

Water Supply Source: Check One **Municipal Water System** **Other than municipal, non-community or private water system. See NR 811 and 812 for definitions.**

Initial Test

RP relief valve Opened at _____ PSID <input type="checkbox"/> Did not open	1 st check <input type="checkbox"/> Closed tight <input type="checkbox"/> Leaked Static _____ PSID	2 nd check <input type="checkbox"/> Closed tight <input type="checkbox"/> Leaked Static _____ PSID
--	--	--

FINAL TEST

Opened at _____ PSID	<input type="checkbox"/> Closed tight Static _____ PSID	<input type="checkbox"/> Closed tight Static _____ PSID
----------------------	--	--

DETECTOR BYPASS ASSEMBLY INITIAL TEST

RP relief valve Opened at _____ PSID <input type="checkbox"/> Did not open	1 st check <input type="checkbox"/> Closed tight <input type="checkbox"/> Leaked Static _____ PSID	2 nd check <input type="checkbox"/> Closed tight <input type="checkbox"/> Leaked Static _____ PSID
--	--	--

DETECTOR BYPASS ASSEMBLY FINAL TEST

Opened at _____ PSID	<input type="checkbox"/> Closed tight Static _____ PSID	<input type="checkbox"/> Closed tight Static _____ PSID
----------------------	--	--

PVB/SRVB INITIAL TEST

Air inlet valve Opened at _____ PSID <input type="checkbox"/> Did not open	Check valve <input type="checkbox"/> Closed tight <input type="checkbox"/> Leaked Static _____ PSID
--	--

PVB/SRVB FINAL TEST

Air inlet valve Opened at _____ PSID	Check Valve <input type="checkbox"/> Closed tight Static _____ PSID
---	---

Assemblies in Fire Protection Systems

Note: Include hose stream demand where applicable

Forward Flow Test Designed flow rate _____ GPM	Actual flow rate _____ GPM
---	----------------------------

Indicating Control Valves

No. one control valve open
 No. two control valves open
 Valve supervision: Tamper switch Locked

Part (s) Replaced/Comments _____

Fee Payment Attached - Make Checks Payable To: DSPS

Total Amount Due: \$30 Per Assembly renewal or \$60 Per New Application

I Hereby Certify the Test Results Are True and the Test Was Conducted by Me Personally.

Tester Name (print) _____ Registration No. _____ Time of Day _____

Tester Signature _____ Phone No. _____ Date _____

Owner Information:

The backflow preventer is a mechanical device designed to protect the potable water supply system from being contaminated. There is a physical connection to equipment or water of either unknown or questionable quality, thereby requiring the installation of the backflow preventer. To ensure that this device is working as designed, it must be periodically tested.

A test shall be conducted on each backflow preventer prior to it being put into service, after any repairs, and a minimum of once a year thereafter.

It is the responsibility of the owner to make sure the device is tested. The test shall be performed by a department registered Cross Connection Control Device tester.

Owner's Contact Person:

The owner's contact person is the name of the person responsible for the backflow preventer maintenance and records. **(Note: Please provide full name.)**

Assembly Replacement Information

If the replacement assembly hasn't moved more than 10 feet and/or the type of assembly hasn't changed, all information for the replacement assembly (manufacturer, model no., serial no., and size) will replace existing information during the renewal process.

If the replacement assembly has moved 10 feet or more and/or the type of assembly has changed, the replacement assembly must be registered as a new assembly. Please submit [Form SBD10766](#) to have the replaced assembly removed from service.

MINIMUM REQUIREMENTS FOR PASSING TEST

Reduced Pressure and Reduced Pressure Detector Fire

- The first check must close tight, and a minimum static PSID of 5 is required.
- The second check must close tight and have a minimum static 1 PSID.
- The relief valve must open at a minimum static 2 PSID.
- The relief valve must not be leaking upon completion of test.

Pressure Vacuum Breaker / Spill Resistant Vacuum Breaker

- The air inlet valve must open at a minimum static 1 PSID.
- The check valve must close tight and have a minimum static 1 PSID.