



VIRTUAL/TELECONFERENCE
FIRE PREVENTION CODE ADVISORY COMMITTEE
Virtual, 4822 Madison Yards Way, Madison
Contact: Brad Wojciechowski (608) 266-2112
July 22, 2026

The following agenda describes the issues that the Committee plans to consider at the meeting. At the time of the meeting, items may be removed from the agenda. Please consult the meeting minutes for a record of the actions of the Committee.

AGENDA

9:30 A.M.

OPEN SESSION – CALL TO ORDER – ROLL CALL

A. Adoption of Agenda (1-2)

B. Approval of Minutes of May 6, 2026 (3-4)

C. Reminders: Conflicts of Interest, Scheduling Concerns

D. Introductions, Announcements and Recognition

E. Administrative Matters – Discussion and Consideration

1. Department, Staff and Committee Updates
2. Section Member – Term Expiration Date
 - a. Bauer, Shoua
 - b. Bending, Brian
 - c. Fehrenbach, Michael
 - d. Hammond, April
 - e. Hornung, Amanda
 - f. Howard, Steven
 - g. Olson, Craig
 - h. Roberts, Jason
 - i. Ruckriegel, Edwin
 - j. Schmocker, Daniel

F. Administrative Rule Matters – Discussion and Consideration (5-13)

1. Discussion of Proposed Updates to SPS 314
2. General Discussion of 2024 NFPA 1 and Changes from Previous Versions
3. Pending or Possible Rulemaking Projects

G. Public Comments

ADJOURNMENT

NEXT MEETING: SEPTEMBER 9, 2026

MEETINGS AND HEARINGS ARE OPEN TO THE PUBLIC, AND MAY BE CANCELLED
WITHOUT NOTICE.

Times listed for meeting items are approximate and depend on the length of discussion and voting. All meetings are held at 4822 Madison Yards Way, Madison, Wisconsin, unless otherwise noted. In order to confirm a meeting or to request a complete copy of the board's agenda, please call the listed contact person. The board may also consider materials or items filed after the transmission of this notice. Times listed for the commencement of disciplinary hearings may be changed by the examiner for the convenience of the parties. Requests for interpreters for the deaf or hard of hearing, or other accommodations, are considered upon request by contacting the Affirmative Action Officer, 608-266-2112, or the Meeting Staff at 608-266-5439.

**VIRTUAL/TELECONFERENCE
FIRE PREVENTION CODE ADVISORY COMMITTEE
MEETING MINUTES
MAY 6, 2026**

PRESENT: Shoua Bauer, Brian Bending, Michael Fehrenbach, April Hammond, Amanda Hornung, Craig Olson, Jason Roberts, Edwin Ruckriegel, Daniel Schmocker

ABSENT: Steven Howard

STAFF: Brad Wojciechowski, Executive Director; Joseph Ricker, Legal Counsel; Tracy Drinkwater, Board Administration Specialist; Aaron Andre, DIS; Steven Komar, DIS; Richard Sommerfeld, DIS; and other Department Staff

CALL TO ORDER

Edwin Ruckriegel, Chairperson, called the meeting to order at 9:30 a.m. A quorum of nine (9) members was confirmed.

ADOPTION OF AGENDA

MOTION: Daniel Schmocker moved, seconded by Shoua Bauer, to adopt the agenda as published. Motion carried unanimously.

APPROVAL OF MINUTES OF FEBRUARY 18, 2026

MOTION: Jason Roberts moved, seconded by Michael Fehrenbach, to approve the minutes of February 18, 2026, as published. Motion carried unanimously.

ADMINISTRATIVE RULE MATTERS

MOTION: Brian Bending moved, seconded by Daniel Schmocker, to approve item number 2b on SPS 314.01 (11) (a) 1. as presented in the May 6, 2026, meeting agenda materials. Motion carried unanimously.

MOTION: Michael Fehrenbach moved, seconded by Jason Roberts, to approve item number 3 on SPS 314.01 (13) (c) 5. as presented in the May 6, 2026, meeting agenda materials. Motion carried unanimously.

MOTION: Michael Fehrenbach moved, seconded by Shoua Bauer, to approve item number 4a on SPS 314.01 (13) (d) 2. as presented in the May 6, 2026, meeting agenda materials. Motion carried unanimously.

MOTION: Amanda Hornung moved, seconded by Jason Roberts, to approve item number 4b on SPS 314.01 (13) (d) 3. as presented in the May 6, 2026, meeting agenda materials for further discussion at future meetings. Motion carried.

MOTION: Craig Olson moved, seconded by Brian Bending, to approve item number 6 on SPS 314.01 (13) (c) 11. as presented in the May 6, 2026, meeting agenda materials for further discussion at future meetings. Motion carried unanimously.

ADJOURNMENT

MOTION: Brian Bending moved, seconded by Jason Roberts, to adjourn the meeting. Motion carried unanimously.

The meeting adjourned at 10:24 a.m.

**State of Wisconsin
Department of Safety & Professional Services**

AGENDA REQUEST FORM

1) Name and title of person submitting the request: Jake Pelegrin Administrative Rules Coordinator		2) Date when request submitted: 7/16/26 Items will be considered late if submitted after 12:00 p.m. on the deadline date which is 8 business days before the meeting											
3) Name of Board, Committee, Council, Sections: Fire Prevention Code Advisory Committee													
4) Meeting Date: 7/22/26	5) Attachments: ☒ Yes ☐ No	6) How should the item be titled on the agenda page? Administrative Rule Matters – Discussion and Consideration 1. Discussion of Proposed Updates to SPS 314 2. General Discussion of 2024 NFPA 1 and Changes from Previous Versions 3. Pending or Possible Rulemaking Projects											
7) Place Item in: ☒ Open Session ☐ Closed Session	8) Is an appearance before the Board being scheduled? <i>(If yes, please complete Appearance Request for Non-DSPS Staff)</i> ☐ Yes ☒ No	9) Name of Case Advisor(s), if required: N/A											
10) Describe the issue and action that should be addressed: Attachments: -Proposed updates to SPS 314 -Reference guide to key changes in NFPA editions													
<table style="width: 100%;"> <tr> <td style="width: 40%;">11)</td> <td style="width: 60%; text-align: right;">Authorization</td> </tr> <tr> <td><i>Jake Pelegrin</i></td> <td style="text-align: right;">7/16/26</td> </tr> </table> <table style="width: 100%;"> <tr> <td style="width: 70%;">Signature of person making this request</td> <td style="width: 30%; text-align: right;">Date</td> </tr> </table> <table style="width: 100%;"> <tr> <td style="width: 70%;">Supervisor (if required)</td> <td style="width: 30%; text-align: right;">Date</td> </tr> </table> <table style="width: 100%;"> <tr> <td style="width: 70%;">Executive Director signature (indicates approval to add post agenda deadline item to agenda)</td> <td style="width: 30%; text-align: right;">Date</td> </tr> </table>				11)	Authorization	<i>Jake Pelegrin</i>	7/16/26	Signature of person making this request	Date	Supervisor (if required)	Date	Executive Director signature (indicates approval to add post agenda deadline item to agenda)	Date
11)	Authorization												
<i>Jake Pelegrin</i>	7/16/26												
Signature of person making this request	Date												
Supervisor (if required)	Date												
Executive Director signature (indicates approval to add post agenda deadline item to agenda)	Date												
Directions for including supporting documents: 1. This form should be attached to any documents submitted to the agenda. 2. Post Agenda Deadline items must be authorized by a Supervisor and the Policy Development Executive Director. 3. If necessary, provide original documents needing Board Chairperson signature to the Bureau Assistant prior to the start of a meeting.													

July 2026 FIRE PREVENTION CODE ADVISORY COMMITTEE
SPS 314

ITEM NO.	CODE/RULE PROVISION	EXISTING LANGUAGE AND PROPOSED CHANGES TO SPS	PROPOSED CODE LANGUAGE	COMMENTS & STATUS
----------	---------------------	---	------------------------	-------------------

New Items July 2026

7	SPS 314.03(1)(de)	314.03 Definitions. (1) These are department definitions for this chapter in addition to the definitions in NFPA 1 chapter 3: ... (de) "First alarm" means the first dispatch of fire personnel and equipment to an incident regardless of the number of firefighters, equipment, or departments dispatched.	314.03 Definitions. (1) These are department definitions for this chapter in addition to the definitions in NFPA 1 chapter 3: ... (de) "First alarm" means the first dispatch of fire personnel and equipment to an incident regardless of the number of firefighters, equipment, or departments dispatched.	Proposed new definition for this term after discussion at the May meeting to clarify how this term is used in SPS 314.01(13)(d)2. Presented by: April Hammond
8	SPS 314.03(1)(f)	314.03 Definitions. (1) These are department definitions for this chapter in addition to the definitions in NFPA 1 chapter 3: ... (f) "NFPA 1" means the 2012 edition of NFPA 1, <i>Fire Code</i>, as adopted and modified in this chapter.	314.03 Definitions. (1) These are department definitions for this chapter in addition to the definitions in NFPA 1 chapter 3: ... (f) "NFPA 1" means the NFPA 1, <i>Fire Code</i>, as adopted and modified in this chapter.	The inclusion of the specific version of the NFPA is redundant in this definition because only one version is adopted in the chapter. Removing the version reference remedies this issue. Presented by: April Hammond
9	SPS 314.01(2)(a)3.b.	314.01 Administration. ... (2) Application. (a) General. Substitute the following wording for the requirements in NFPA 1 sections 1.3.2.4. to 1.3.2.4.3: ... 3. ... b. The requirements in NFPA 1 sections 18.2.3 and 18.3 do not apply to buildings constructed prior to September 1, 2014. Buildings constructed prior to that date but on or after March 1, 2008, shall comply with the requirements in NFPA 1 sections 18.2.3 and 18.3 which were in effect under this subdivision during that period. The requirement in NFPA 1 section 18.2.2.1 that an access box be listed in accordance with UL 1037 does not apply to access boxes installed prior to September 1, 2014.	Committee to discuss whether they think any changes are needed.	Traffic signal pre-emption requirements have changed. Some municipalities may not want traffic signal pre-emption for all traffic lights. Many municipalities only use this on their major roads due to cost. Should there be an exception to allow municipalities to exclude this? Presented by: April Hammond
10	SPS 314.01(2)(a)4.	314.01 Administration. ... (2) Application. (a) General. Substitute the following wording for the requirements in NFPA 1 sections 1.3.2.4. to 1.3.2.4.3: ... 4. The design requirements in NFPA 1 sections 50.2.1.1 and 50.4 for an exhaust hood and an automatic fire suppression system are included as part of this chapter, for mobile kitchens only.	Committee to discuss whether they think any changes are needed.	2024 NFPA 50.4, 50.5, and 50.8 had substantial content changes related to cooking operations. A specific section was created for Mobile and Temporary Kitchens that didn't exist previously. DIS requests that the Committee review and identify any areas of concern or provisions that should be excluded or changed in SPS 314? DIS would ask the Committee to look through all of 50.8 to see if there are any recommended exclusions. Presented by: April Hammond

11	SPS 314.01(6)	314.01 Administration. ... (6) Interpretations, <u>rules, and regulations</u>. These are department rules in addition to the requirements in NFPA 1 section 1.7.3:	314.01 Administration. ... (6) Interpretations, rules, and regulations. These are department rules in addition to the requirements in NFPA 1 section 1.7.3:	The title for the referenced section changed between the 2012 and 2024 editions of NFPA 1. DSPS recommends updating the title to remain consistent with NFPA 1. Presented by: April Hammond
12	SPS 314.01(7)(a)	314.01 Administration. ... (7) Exclusions. (a) 1. The requirements in the following NFPA 1 sections are not included as part of this chapter: 1.7.10.2 <u>1.7.11.2</u>, 1.7.10.4; 1.9.1 to 1.9.3, and 1.10. 2. Any permit referenced in NFPA 1 section 1.12 <u>1.13</u> or referred to elsewhere under this chapter is not required by this chapter, but may be required at the local level if done so through a local ordinance. 3. Any certificate of fitness referenced in NFPA 1 section 1.13 <u>1.14</u> or referred to elsewhere under this chapter is not required by this chapter, but may be required at the local level if done so through a local ordinance.	314.01 Administration. ... (7) Exclusions. (a) 1. The requirements in the following NFPA 1 sections are not included as part of this chapter: 1.7.11.2, 1.9.1 to 1.9.3, and 1.10. 2. Any permit referenced in NFPA 1 section 1.13 or referred to elsewhere under this chapter is not required by this chapter, but may be required at the local level if done so through a local ordinance. 3. Any certificate of fitness referenced in NFPA 1 section 1.14 or referred to elsewhere under this chapter is not required by this chapter, but may be required at the local level if done so through a local ordinance.	
12a	SPS 314.01(7)(a)1.	314.01 (7) (a) 1. The requirements in the following NFPA 1 sections are not included as part of this chapter: 1.7.10.2 <u>1.7.11.2</u>, 1.7.10.4; 1.9.1 to 1.9.3, and 1.10.	314.01 (7) (a) 1. The requirements in the following NFPA 1 sections are not included as part of this chapter: 1.7.11.2, 1.9.1 to 1.9.3, and 1.10.	The referenced section of NFPA 1 was renumbered from 1.7.10.2 to 1.7.11.2. between the 2012 edition and the 2024 edition. The proposed change updates the reference to maintain consistency. 1.7.10.4 on Trade Secrets was removed from 2024 NFPA with no obvious replacement. Since this was already being excluded in SPS 314, DIS recommends simply striking this reference. Presented by: April Hammond
12b	SPS 314.01(7)(a)2.	314.01 (7) (a) 2. Any permit referenced in NFPA 1 section 1.12 <u>1.13</u> or referred to elsewhere under this chapter is not required by this chapter, but may be required at the local level if done so through a local ordinance.	314.01 (7) (a) 2. Any permit referenced in NFPA 1 section 1.13 or referred to elsewhere under this chapter is not required by this chapter, but may be required at the local level if done so through a local ordinance.	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition. The proposed change updates the reference to maintain consistency. Presented by: April Hammond
12c	SPS 314.01(7)(a)3.	314.01 (7) (a) 3. Any certificate of fitness referenced in NFPA 1 section 1.13 <u>1.14</u> or referred to elsewhere under this chapter is not required by this chapter, but may be required at the local level if done so through a local ordinance.	314.01 (7) (a) 3. Any certificate of fitness referenced in NFPA 1 section 1.14 or referred to elsewhere under this chapter is not required by this chapter, but may be required at the local level if done so through a local ordinance.	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition. The proposed change updates the reference to maintain consistency. Presented by: April Hammond
13	SPS 314.01(7m)	314.01 Administration. ... (7m) Stop orders. This is a department informational note to be used under NFPA 1 section 1.7.14 <u>1.7.15</u>:	314.01 Administration. ... (7m) Stop orders. This is a department informational note to be used under NFPA 1 section 1.7.15:	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition. The proposed change updates the reference to maintain consistency. Presented by: April Hammond

14	SPS 314.01(11)	314.01 Administration. ... (11) Fire incident reports. Substitute the following wording for the requirements in NFPA 1 section 1.12.4.2 <u>1.12.4.2</u> :	314.01 Administration. ... (11) Fire incident reports. Substitute the following wording for the requirements in NFPA 1 section 1.12.4.2:	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition. The proposed change updates the reference to maintain consistency. Presented by: April Hammond
15	SPS 314.01(11m)	314.01 Administration. ... (11m) Records with a register of deeds. Any text in NFPA 1 section 1.13.3 <u>1.13.3</u> that permits an authority having jurisdiction, as defined in NFPA 1 section 3.2.2, to require recording anything at a register of deeds office is not included as part of this chapter.	314.01 Administration. ... (11m) Records with a register of deeds. Any text in NFPA 1 section 1.13.3 that permits an authority having jurisdiction, as defined in NFPA 1 section 3.2.2, to require recording anything at a register of deeds office is not included as part of this chapter.	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition. The proposed change updates the reference to maintain consistency. Presented by: April Hammond
16	SPS 314.01(12)	314.01 Administration. ... (12) Penalties. This is a department rule in addition to the requirements in NFPA 1 section 1.17 <u>1.17</u> : Penalties for violations of this chapter shall be assessed in accordance with s. 101.02 (12) and (13) (a), Stats.	314.01 Administration. ... (12) Penalties. This is a department rule in addition to the requirements in NFPA 1 section 1.17: Penalties for violations of this chapter shall be assessed in accordance with s. 101.02 (12) and (13) (a), Stats.	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition. The proposed change updates the reference to maintain consistency. Presented by: April Hammond
17	SPS 314.03(2)	314.03 Definitions. ... (2) Substitute the following definition for the definition in NFPA 1 section 3.3.182.22 <u>3.3.203.25</u> : “One- and 2-family dwelling” has the meaning as defined for dwelling in s. 101.61 (1), Stats. Note: Section 101.61 (1) of the Statutes reads as follows: “‘Dwelling’ means any building that contains one or 2 dwelling units. ‘Dwelling unit’ means a structure or that part of a structure which is used or intended to be used as a home, residence or sleeping place by one person or by 2 or more persons maintaining a common household, to the exclusion of all others. <u>“Dwelling” and “dwelling unit” do not include a primitive rural hunting cabin.</u> ”	314.03 Definitions. ... (2) Substitute the following definition for the definition in NFPA 1 section 3.3.203.25: “One- and 2-family dwelling” has the meaning as defined for dwelling in s. 101.61 (1), Stats. Note: Section 101.61 (1) of the Statutes reads as follows: “‘Dwelling’ means any building that contains one or 2 dwelling units. ‘Dwelling unit’ means a structure or that part of a structure which is used or intended to be used as a home, residence or sleeping place by one person or by 2 or more persons maintaining a common household, to the exclusion of all others. “Dwelling” and “dwelling unit” do not include a primitive rural hunting cabin.”	
17a	SPS 314.03(2)	314.03 (2) Substitute the following definition for the definition in NFPA 1 section 3.3.182.22 <u>3.3.203.25</u> : “One- and 2-family dwelling” has the meaning as defined for dwelling in s. 101.61 (1), Stats.	314.03 (2) Substitute the following definition for the definition in NFPA 1 section 3.3.203.25: “One- and 2-family dwelling” has the meaning as defined for dwelling in s. 101.61 (1), Stats.	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition. The proposed change updates the reference to maintain consistency. Presented by: April Hammond
17b	SPS 314.03(2)Note	314.03 (2) Note: Section 101.61 (1) of the Statutes reads as follows: “‘Dwelling’ means any building that contains one or 2 dwelling units. ‘Dwelling unit’ means a structure or that part of a structure which is used or intended to be used as a home, residence or sleeping place by one person or by 2 or more persons maintaining a common household, to the exclusion of all others. <u>“Dwelling” and “dwelling unit” do not include a primitive rural hunting cabin.</u> ”	314.03 (2) Note: Section 101.61 (1) of the Statutes reads as follows: “‘Dwelling’ means any building that contains one or 2 dwelling units. ‘Dwelling unit’ means a structure or that part of a structure which is used or intended to be used as a home, residence or sleeping place by one person or by 2 or more persons maintaining a common household, to the exclusion of all others. “Dwelling” and “dwelling unit” do not include a primitive rural hunting cabin.”	The definition in s. 101.61(3), Stats., has been updated since the last code cycle. This amendment updates the definition to reflect current statutory language. Presented by: April Hammond

18	SPS 314.10	314.10 General fire safety. ... (2) Emergency action plans. This is a department informational note to be used under NFPA 1 section 10.9.2.2 <u>10.4.2.2</u>: (2m) Open flames. Substitute the following wording for the requirements in NFPA 1 section 10.11.2 <u>10.10.2</u>: The AHJ shall have the authority to prohibit any or all open flames, and open, recreational, and cooking fires or other sources of ignition, or establish special regulations on the use of any form of fire or smoking material where circumstances make such conditions hazardous. (2r) Cooking equipment on balconies. Substitute the following wording for the requirements in NFPA 1 section 10.11.6.2 <u>10.10.6.1</u>: For other than one- and two-family dwellings, no fuel for a hibachi, grill, or other similar device used for cooking may be stored with that equipment on a balcony. (3) Christmas trees. ... (b) This is a department informational note to be used under NFPA 1 section 10.14 <u>10.13</u>: -Note: Guidance on use of natural-cut Christmas trees is available at the Department's Web site at http://dsps.wi.gov through links to the Fire Prevention program in the Division of Industry Services.	314.10 General fire safety. ... (2) Emergency action plans. This is a department informational note to be used under NFPA 1 section 10.4.2.2: (2m) Open flames. Substitute the following wording for the requirements in NFPA 1 section 10.10.2: The AHJ shall have the authority to prohibit any or all open flames, and open, recreational, and cooking fires or other sources of ignition, or establish special regulations on the use of any form of fire or smoking material where circumstances make such conditions hazardous. (2r) Cooking equipment on balconies. Substitute the following wording for the requirements in NFPA 1 section 10.10.6.1: For other than one- and two-family dwellings, no fuel for a hibachi, grill, or other similar device used for cooking may be stored with that equipment on a balcony. (3) Christmas trees. ...	
18a	SPS 314.10(2)	314.10 (2) Emergency action plans. This is a department informational note to be used under NFPA 1 section 10.9.2.2 <u>10.4.2.2</u>:	314.10 (2) Emergency action plans. This is a department informational note to be used under NFPA 1 section 10.4.2.2:	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition and the title was amended. The proposed change updates the reference to maintain consistency. Presented by: April Hammond
18b	SPS 314.10(2m)	314.10 (2m) Open flames. Substitute the following wording for the requirements in NFPA 1 section 10.11.2 <u>10.10.2</u>: The AHJ shall have the authority to prohibit any or all open flames, and open, recreational, and cooking fires or other sources of ignition, or establish special regulations on the use of any form of fire or smoking material where circumstances make such conditions hazardous.	314.10 (2m) Open flames. Substitute the following wording for the requirements in NFPA 1 section 10.10.2: The AHJ shall have the authority to prohibit any or all open flames, and open, recreational, and cooking fires or other sources of ignition, or establish special regulations on the use of any form of fire or smoking material where circumstances make such conditions hazardous.	The NFPA 1 - 2024 language directly mirrors the substitute language in the existing SPS 314.10(2r) with the addition of fireworks. DIS recommendation is to repeal this section and allow the NFPA language to control. Presented by: April Hammond
18c	SPS 314.10(2r)	314.10 (2r) Cooking equipment on balconies. Substitute the following wording for the requirements in NFPA 1 section 10.11.6.2 <u>10.10.6.1</u>: For other than one- and two-family dwellings, no fuel for a hibachi, grill, or other similar device used for cooking may be stored with that equipment on a balcony.	314.10 (2r) Cooking equipment on balconies. Substitute the following wording for the requirements in NFPA 1 section 10.10.6.1: For other than one- and two-family dwellings, no fuel for a hibachi, grill, or other similar device used for cooking may be stored with that equipment on a balcony. <i>Committee to discuss if they think any changes are needed.</i>	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition and the title was amended. The proposed change updates the reference to maintain consistency. Additionally, this section contains the requirements for storage of grills and other fueled devices on balconies. Given previous discussion on this subject DIS is seeking input on any recommended changes to this section. Presented by: April Hammond

18d	SPS 314.10(3)(b)	314.10 (3) (b) This is a department informational note to be used under NFPA 1 section 10.14. Note: Guidance on use of natural cut Christmas trees is available at the Department's Web site at http://dps.wi.gov through links to the Fire Prevention program in the Division of Industry Services.	N/A (Code Language Removed)	DIS proposes repeal of this note. The guidance referenced is outdated, consumers are unlikely to consult the administrative code for guidance on Christmas tree storage, and more current guidance is readily available from public sources. Presented by: April Hammond
19	SPS 314.13(2)	SPS 314.13 Fire protection systems. ... (2) Credentials for testers of fire sprinkler systems. This is a department informational note to be used under NFPA 1 section 13.3.3: Note: Chapter SPS 305 contains credential requirements for testers of fire sprinkler systems. That chapter and this chapter do not preclude non-credentialed individuals from conducting the daily, weekly, monthly, quarterly or semiannual inspection and testing activities for automatic fire sprinkler systems required under NFPA 25 and NFPA 72. (3) This is a department informational note to be used under NFPA 1 section 13.6.4.1.2: (4) Substitute the following informational note for the requirements in NFPA 1 sections 13.7.1.14 and 13.7.2.9.4 13.7.2.15.6.1 to 13.7.2.9.4.4 13.7.2.15.6.4: Note: See s. 101.149, Stats., and chapters SPS 361 to 366 for requirements relating to installation and maintenance of carbon monoxide alarms.	SPS 314.13 Fire protection systems. ... (3) This is a department informational note to be used under NFPA 1 section 13.6.4.1.2: (4) Substitute the following informational note for the requirements in NFPA 1 sections 13.7.1.14 and 13.7.2.15.6.1 to 13.7.2.15.6.4: Note: See s. 101.149, Stats., and chapters SPS 361 to 366 for requirements relating to installation and maintenance of carbon monoxide alarms.	
19a	SPS 314.13(2)	314.13 (2) Credentials for testers of fire sprinkler systems. This is a department informational note to be used under NFPA 1 section 13.3.3: Note: Chapter SPS 305 contains credential requirements for testers of fire sprinkler systems. That chapter and this chapter do not preclude non-credentialed individuals from conducting the daily, weekly, monthly, quarterly or semiannual inspection and testing activities for automatic fire sprinkler systems required under NFPA 25 and NFPA 72.	N/A (Code Language Removed)	DIS proposes repeal of this note because it may cause confusion regarding who may perform the specific inspections referenced. Presented by: April Hammond
19b	SPS 314.13(3)	314.13 (3) This is a department informational note to be used under NFPA 1 section 13.6.9.1.2 13.6.4.1.2:	314.13 (3) This is a department informational note to be used under NFPA 1 section 13.6.4.1.2:	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition. The proposed change updates the reference to maintain consistency. Presented by: April Hammond
19c	SPS 314.13(4)	314.13 (4) Substitute the following informational note for the requirements in NFPA 1 sections 13.7.1.14 and 13.7.2.9.4 13.7.2.15.6.1 to 13.7.2.9.4.4 13.7.2.15.6.4:	314.13 (4) Substitute the following informational note for the requirements in NFPA 1 sections 13.7.1.14 and 13.7.2.15.6.1 to 13.7.2.15.6.4:	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition. The proposed change updates the reference to maintain consistency. Presented by: April Hammond
19d	SPS 314.13(4)Note:	314.13 (4) Note: See s. 101.149, Stats., and chapters SPS 361 to 366 for requirements relating to installation and maintenance of carbon monoxide alarms.	314.13 (4) Note: See s. 101.149, Stats., and chapters SPS 361 to 366 for requirements relating to installation and maintenance of carbon monoxide alarms.	Regulations related to installation and maintenance of carbon are now primarily located in Wis. Stat. s. 101.149. DIS proposes updating the reference to include the statute reference in addition to the existing reference to chs. SPS 361 to 366. Presented by: April Hammond

19e	SPS 314.13(5)	314.13 (5) Maintenance of smoke detectors and alarms. These are department informational notes to be used under NFPA 1 section 13.7.4.6 13.7 :	314.13 (5) Maintenance of smoke detectors and alarms. These are department informational notes to be used under NFPA 1 section 13.7:	The internal structure of NFPA 1 section 13.7 was significantly modified between 2012 and 2024, however the substance of the note in SPS 314.13(5) applies to all of section 13.7 regardless of the organization of the materials. DIS proposes updating the reference to all of NFPA 13.7 to avoid confusion. Presented by: April Hammond
20	SPS 314.16	314.16 Hose threads during construction. These are department informational notes to be used under NFPA 1 section 16.4.3.3.2.6 16.1.1 :	314.16 Hose threads during construction. These are department informational notes to be used under NFPA 1 section 16.1.1: <i>Committee to discuss if they think any changes are needed.</i>	Requirements previously contained in NFPA 1 section 16.4.3.3.2.6 are now included in NFPA 241. Compliance with NFPA 241 is currently referenced in NFPA 1 section 16.1.1. DIS is seeking input on whether it is more appropriate to amend this note to reference section 16.1.1., or to remove the note. Presented by: April Hammond
21	SPS 314.50	314.50 Commercial cooking equipment for mobile kitchens. This is a department exception to the requirements in NFPA 1 sections 50.2.1.1 and 50.4 50.5 : Neither an exhaust hood nor an automatic fire suppression system is required for a mobile kitchen where all of the following conditions are met: (1) The kitchen is less than 365 square feet in size. (2) The kitchen is used on fewer than 12 days in a calendar year, for the purpose of cooking. (3) The owner or operator of the kitchen maintains a record demonstrating compliance with sub. (2), retains the record with the kitchen, and makes the record available to an inspector upon request.	314.50 Commercial cooking equipment for mobile kitchens. This is a department exception to the requirements in NFPA 1 sections 50.2.1.1 and 50.5: Neither an exhaust hood nor an automatic fire suppression system is required for a mobile kitchen where all of the following conditions are met: (1) The kitchen is less than 365 square feet in size. (2) The kitchen is used on fewer than 12 days in a calendar year, for the purpose of cooking. (3) The owner or operator of the kitchen maintains a record demonstrating compliance with sub. (2), retains the record with the kitchen, and makes the record available to an inspector upon request.	The referenced section of NFPA 1 was renumbered between the 2012 edition and the 2024 edition. The proposed change updates the reference to maintain consistency. Presented by: April Hammond



A Reference Guide to Key Changes in the 2012 - 2024 Editions of NFPA 1: Fire Code

Changes in the 2012 edition of NFPA 1: Fire Code

- Sprinklers in all new buildings three or more stories in height
- CO detection in new residential occupancies reflecting the NFPA 101: Life Safety Code
- Floor fire protection for new non-sprinklered one- and two-family dwellings
- Two-way radio communication enhancement systems may be required by the AHJ per NFPA 72: National Fire Alarm and Signaling Code
- Changes that benefit building occupant safety

Changes in the 2015 edition of NFPA 1: Fire Code

- Chapter 18 includes mandatory requirements on fire hydrant location and distribution -- to assist designers with planning and AHJs and other authorities with inspections.
- Added mandates for carbon monoxide detection and alarm for new educational and new day care facilities and other changes reflect safeguards in the 2015 *NFPA 101*.
- Coverage of fire alarm systems for occupancies now mirrors *NFPA 101* to provide additional information and reduce reference time.

Changes in the 2018 edition of NFPA 1: Fire Code

- Newly added references for the professional qualifications for fire inspectors, plan examiners, and fire marshals
- Revised requirements for the application of referenced publications
- New minimum fire prevention inspection frequencies for existing occupancies
- Updates to premises identification
- New and updated marking and access criteria for photovoltaic systems
- New provisions for rubberized asphalt melters
- Listing requirements for electric gates used on fire department access roads
- New provisions on the outside storage of biomass feedstock
- New requirements for the outdoor storage of wood and wood composite pallets or listed pallets equivalent to wood
- All-new Chapter 38 on marijuana growing, processing, or extraction facilities
- Revised Chapter 40 to replace extracts from *NFPA 654* with extracted provisions from *NFPA 652*
- Completely reorganized aircraft fuel servicing provisions in accordance with *NFPA 407*
- A new section on mobile and temporary cooking operations

- Extensive revisions of Chapter 52 on energy storage systems
- All-new Chapter 55 on cleaning and purging of flammable gas piping systems with reference to *NFPA 56*
- New provisions for insulated liquid carbon dioxide systems extracted from *NFPA 55*
- New Annex E on fire fighter breathing-air replenishment systems

Changes in the 2021 edition of *NFPA 1: Fire Code*

- The vexing problem of valet trash
- The new Chapter 46 separates 3D printing into two sub-categories: industrial additive manufacturing and nonindustrial
- New cannabis guidance - Chapter 38, “Marijuana Growing, Processing, or Extraction Facilities” Updates
- New warning required for non-sprinklered high-rises
- Prohibition of consumer fireworks

Changes in the 2024 edition of *NFPA 1: Fire Code*

- Outdoor Use of Electrically Powered Cooking Appliances: Amended requirements for residential use.
- Powered Micro-Mobility Devices: Introduction of new regulations for e-bikes and e-scooters.
- In-Building Emergency Communication Systems: Enhanced requirements for emergency responder communication.
- QR Code Transition: Replacing marginal markings with QR codes for identifying technical changes.