

**SPS 380-387 PLUMBING CODE ADVISORY COMMITTEE
MEETING MINUTES
AUGUST 9, 2017**

PRESENT: Scott Chiples, Fred Gardner, Roger Musolff, Marc Rhiner, Robert Schmidt, Jason Sladky, Joseph Zoulek

STAFF: Melinda Allen, Administrative Rules Coordinator; Tom Braun, Section Chief; Ryan Boebel, Plumbing Consultant; Laura Smith, Bureau Assistant; and other Department staff

Roger Musolff, Section Chief, called the meeting to order at 9:00 a.m. A majority of seven (7) members was present.

ADOPTION OF AGENDA

- *Add under item A, include "Approval of the Minutes of June 14, 2017"*

MOTION: Roger Musolff moved, seconded by Jason Sladky, to adopt the agenda as amended. Motion carried unanimously.

APPROVAL OF MINUTES

MOTION: Jason Sladky moved, seconded by Fred Gardner, to approve the minutes of June 14, 2017 as published. Motion carried unanimously.

LEGISLATIVE AND ADMINISTRATIVE RULE MATTERS

Discussion of Department and Advisory Committee Proposed Code Changes Relating to the Plumbing Code, SPS 381-387

SPS 382: Design, Construction, Installation, Supervision, Maintenance, and Inspection of Plumbing and SPS 382 Appendix

MOTION: Robert Schmidt moved, seconded by Fred Gardner, to include a definition of 'seasonal' to mean for use between the dates of April 15 to October 31 for the purpose of frost protection. Motion carried unanimously.

MOTION: Marc Rhiner moved, seconded by Robert Schmidt, to place a note under table 382.30-1 to read 'See SPS 382.32(3)(e) for exceptions'. Motion carried unanimously.

MOTION: Jason Sladky moved, seconded by Scott Chiples, to eliminate the phrase 'but not limited to' from, and in its place add 'other devices, fixtures and appliances as approved by the Department' to the table 382.33. Motion carried unanimously.

MOTION: Roger Musolff moved, seconded by Joseph Zoulek, to add 'icemakers' after 'ice compartments' and 'related equipment' after 'steam tables and kettles', to Table 382.33-1. Motion carried unanimously.

MOTION: Joseph Zoulek moved, seconded by Fred Gardner, to request that the Department draft language for 382.50 relating to dialysis boxes. Motion carried unanimously.

MOTION: Fred Gardner moved, seconded by Robert Schmidt, to amend 382.40(3)(e) to read 'Except that the piping system serving the fire sprinkler of a multi-purpose system may

be designed to exceed velocity of 8 feet per second upon the activation of a sprinkler'. Motion carried unanimously.

MOTION: Roger Musolff moved, seconded by Scott Chiples, to amend 382.40(7)(e) to read 'a water distribution system shall be designed such that the water velocity shall not exceed 8 feet per second, except as provided in 382.40(3)(e). Motion carried unanimously.

MOTION: Roger Musolff moved, seconded by Robert Schmidt, to amend the term 'material' and replace with the word 'information', where appropriate, throughout the Plumbing Code. Motion carried unanimously.

MOTION: Robert Schmidt moved, seconded by Marc Rhiner, to table 41-45 until the Committee can see a formal copy of 1002. Motion carried unanimously.

MOTION: Robert Schmidt moved, seconded by Jason Sladky, to create 382.37(3)(b)(4) to read 'Water supply systems shall be provided with provisions for effective flushing of the system, at a minimum of ten feet per second until clear'. Motion carried unanimously.

MOTION: Robert Schmidt moved, seconded by Joseph Zoulek, to add a note under 382.37(3)(b)4. to read 'See Appendix 382 for additional information.' Motion carried unanimously.

MOTION: Robert Schmidt moved, seconded by Jason Sladky, to add Table 10.10.2.1.3 into Appendix 382. Motion carried unanimously.

MOTION: Roger Musolff moved, seconded by Jason Sladky, to recommend that the current NFPA standard shall be referenced in 382.40(3)(e). Motion carried unanimously.

MOTION: Robert Schmidt moved, seconded by Fred Gardner, to amend 382.40(7)(d)1. to accept the proposed language change. Motion carried unanimously.

MOTION: Jason Sladky moved, seconded by Scott Chiples, to amend 382.40(8)(b)10. to read 'Private water mains shall be provided with provisions for effective flushing of the system, at a minimum of ten feet per second until clear.', and to add a note in Appendix 382 referring to Table 10.10.2.1.3. Motion carried unanimously.

MOTION: Joseph Zoulek moved, seconded by Scott Chiples, to accept the proposed language change to 382.40(8)(d)7. Motion carried unanimously.

MOTION: Robert Schmidt moved, seconded by Jason Sladky, to add a Table to Appendix 382 similar to 10.10.2.1.3 but aiming at 8 feet per second flow rate for nominal pipe sizes. Motion carried unanimously.

MOTION: Roger Musolff moved, seconded by Jason Sladky, to table discussion of Item 51. Motion carried unanimously.

MOTION: Fred Gardner moved, seconded by Robert Schmidt, to define in 381.01(68) 'water supply system dead end' as 'any part of the water distribution system terminating by means of a plug, cap, or other closed fitting and with no outlet'. Motion carried unanimously.

MOTION: Robert Schmidt moved, seconded by Scott Chiples, to adopt the Department's proposed language from item 52 where indicated and use to create 382.40(8)(i)5. regarding dead ends. Motion carried unanimously.

ADJOURNMENT

MOTION: Robert Schmidt moved, seconded by Joseph Zoulek, to adjourn the meeting. Motion carried unanimously.

The meeting adjourned at 3:41 p.m.