



## State of Wisconsin

### DEPARTMENT OF SAFETY AND PROFESSIONAL SERVICES

#### **Wis. Admin. Code § SPS 316 Requirements** **Effective January 1, 2020**

1. Is an electrical permit and inspection required under Wis. Admin. Code § SPS 316 for a camping pedestal on private property?

**No, this type of installation is not permitted or inspected under the requirements of Wis. Admin. Code § SPS 316. The applicant may request an inspection if desired. Also, check your local municipality for requirements as the municipality can still accept affidavits for installations not covered under Wis. Admin. Code § SPS 316.**

2. Is an electrical permit and inspection required under Wis. Admin. Code § SPS 316 for a pedestal in a public right-of-way?

**Yes, if the purpose of the pedestal is to serve any of the locations identified in [Wis. Admin. Code § SPS 316.012\(1\)\(a\)](#).**

3. Is an electrical inspection required under Wis. Admin. Code § SPS 316 for conduit that is installed for electrical service but does not yet contain electrical wire?

**No, the conduit does not need an electrical inspection prior to electrical wiring installation but the conduit and wiring shall be inspected prior to concealing or energizing, in accordance with [Wis. Admin. Code § SPS 316.013\(3\)\(c\)](#).**

4. Can existing industrial or manufacturing facilities obtain an electrical permit or inspection?

**No municipality delegated under [Wis. Admin. Code § SPS 316.011\(1\)](#) may require an electrical permit or inspection of any installation, repair, or maintenance of electrical wiring within an existing industrial facility or an existing manufacturing facility per the requirements of [Wis. Stat. §§ 101.82\(2m\)](#) [which is ultimately the Statute that allows the Department to develop Wis. Admin. Code § SPS 316] and [101.875\(2\)](#). If the owner requests an inspection, the Department or the delegated municipality may perform these types of inspections to the extent possible with available resources. However, the Department or the delegated municipality is not required under law to inspect these types of installations.**