

Wisconsin Department of Safety and Professional Services
Division of Industry Services
Fire Prevention Program
PO Box 7302
Madison WI 53707-7302



Phone: 608-266-2112
Web: <http://dsps.wi.gov>
Email: dsps@wisconsin.gov

Tony Evers, Governor
Dawn B. Crim, Secretary

06/25/2015

Q & A

NFPA 1 (2012) Section 10.11.6. Does NFPA 1 Section 10.11.6.1 apply to electric grills? (submitted September 2014)

Yes. Under section SPS 314.01 (6) (a) Interpretations. Department authority., the Department has determined that an electric grill is one of the similar devices which are referenced in NFPA 1 section 10.11.6.1 and therefore cannot be used on the balconies and at the other locations described in that section – unless the grill is listed *for that use* and does not have an exposed heating element.