



April 16, 2015

Sheboygan County Planning and Conservation Department
Aaron Brault, Director
508 New York Avenue
Sheboygan, WI 53081-4126

Subject: Plan Review Delegation Request

Dear Mr. Brault:

This letter is in regards to your application dated March 17, 2015 to Bradley Johnson of the Department requesting plan review delegation authority to review replacement septic tanks and pump tanks for plans that were previously approved at the state level. Under s. SPS Table 383.22-2 (1) plan review authority under this delegation is limited and approved for POWTS that will completely utilize treatment and dispersal technologies or methods either approved under s. SPS 384.10 (2) or (3) or recognized under s. SPS 383.60 (1). Replacement septic tanks and pump tanks reviewed under your delegated authority must have product approval from the DPS and is generally limited to those systems with design capacities less than 5,000 gallons per day unless the entire system was previously designed to meet the specifications of a component manual with an alternate design capacity limitation.

Please contact Brad Johnson, POWTS Program Section Chief at (920) 492-5605 if you have any questions and to discuss any training that is needed to successfully meet the objectives of this new delegation.

Sincerely,

Jeff Weigand, Administrator
Division of Industry Services

Cc: Brad Johnson