



August 29, 2011

SKAW PRE-CAST  
JACK SKAW  
26255 105TH ST.  
NEW AUBURN WI 54757

Re: Description: **SEWAGE TREATMENT APPARATUS & TANK SYSTEM [SEE STA -SEWAGE TREATMENT APPARATUS] \***

Manufacturer: SKAW PRE-CAST

Product Name: HIGH STRENGTH FAST 1.0 OR 1.5 AND MICRO FAST 0.5 OR 0.9

Model Number(s): 350/450 (2-COMPARTMENT)

**[47.0 IN. L.L.; 96 IN. MAX. DEPTH OF BURY; TANK DIMENSIONS = 154 IN. L X 77 IN. W X 47 IN. H; FOR TREATMENT PERFORMANCE SEE APPROVAL LETTER FOR INSERTED DEVICE]**

Product File No: 20110272

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of DECEMBER 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank may only be used when installed with the Bio-Microbics, Inc., High Strength or Micro Fast sewage treatment apparatus.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This tank may ONLY be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.
- This product is approved to use the following:
  - Four inch pipe inlet located in the edge of the tank cover.
  - Four inch discharge opening in riser.
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Four inch pipe openings located near the bottom of the side or end wall for siphon, pump and holding tanks.
  - Steel locking cover for the access opening.
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Eight inch threaded plugged opening in access cover.
  - Six-inch diameter opening in lower portion of the interior wall for siphon, pump and holding tanks.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
  - Press Seal "Cast-A-Seal" gasket by Press Seal Gasket Corp.

- **Also refer to the Commerce product approval stipulations for the sewage treatment apparatus, which may include: maximum daily wastewater flow, influent strength, maximum BOD5, and maintenance intervals.**
- **TANK BEDDING:** After excavating to grade, the floor of the tank hole must have all rocks removed that are golf ball size or larger. This applies to soil that is not hard packed clay or rock. If the floor of the hole is hard packed clay or rock, then the hole must be dug deeper to accommodate a lift for sand (no rock) at least 3 inches deep to bring the excavation to the desired grade level.
- **Each tank that is utilized in the installation of this product must pass a water tightness test after installation. The water tightness test must comply with s. Comm. 84.25 (2) of the Wis. Adm. Code.**
- **This approval remains in effect until the expiration date or until the approval of MICRO FAST 0.5, 0.75, or 0.9 are no longer in effect.**
- **This system must have an adequately sized septic tank for the design upstream of this unit.**
- **Backfilling:** When a tank is ready to be buried/backfilled, start by using a backhoe and gently place material on the cover of the tank. At the same time gently place material starting at the corners of the tank. Allow the material placed on the corners to slide down towards the center of the side walls and ends of the tank. This should be done at all corners of the tank at the same time so the tank does not slide around in the bottom of the hole.  
NOTE 1: Too much material applied to any one side of the tank without material on the other side or top of the tank may cause the sidewalls of the tank to crack or slide the tank horizontally in the bottom of the hole.  
NOTE 2: When applying any material as backfill or bury always lower your backhoe bucket to an elevation near (within 12 inches) the grade of the tank cover and empty the bucket of the backhoe slowly. This prevents a large amount of material from "plopping" downward suddenly causing undue stress to the vertical walls and cover of tank.  
NOTE 3: Rocks or stones any larger than 4 inches in diameter should not come into contact with any part of the concrete tank structure at any time.  
WARNING: Stones or rocks larger than 4 inches in diameter could damage the structure of the tank. This can happen especially if the larger stone or rock falls or rolls into contact with any part of the tank structure.  
When finish grading is being accomplished, never drive equipment directly on top of the tank installation. Do not allow tires or tracks of equipment to travel parallel to the tank on material that has just been used to fill the void between the tank and material that has not been disturbed.

**To better clarify this plumbing product, the product type description has been changed from 'sewage tank systems' (STA) to 'SEWAGE TREATMENT APPARATUS & TANK SYSTEM' (STATS). Approved levels of treatment for the inserted SEWAGE TREATMENT APPARATUS are found in the approval letter for the specific device(s).**

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060516. This approval supersedes the approval issued on 12/27/2006 under product file number 20060516.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Products Review  
DSPS WEST, Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@WI.GOV