



October 4, 2011

SIM / TECH FILTER
KOTESKEY BROTHERS EXCAVATING INC.
GARY KOTESKEY
06598 HORTON BAY N RD.
BOYNE CITY MI 49712

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER
Manufacturer: SIM / TECH FILTER
Product Name: SEPTIC TANK GRAVITY FILTER
Model Number(s): STF-110
[MAX. DWF 1200 GPD; FILTRATION > 1/16 IN. DIA.; INSTALL AS SINGLE OR MULTIPLES]
Product File No: 20110295

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of NOVEMBER 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- The label required by s. Comm 83.15 (2) (d), Wis. Admin. Code, must indicate the septic capacity and the pump chamber capacity.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- This product may only be installed in the outlet tee baffle of septic tanks or compartments that have a maximum daily flow rate of no more than 1200 gallons per day.
- MAINTENANCE: Clean filter at inspection/pumping interval.
- **Additional information is included as attachment(s) to this letter; see attachment A.**

This approval supersedes the approval issued on 9/10/2009 under product file number 20060438.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060438.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
DSPS WEST, Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@WI.GOV
SBD-10564-E (N.10/97)