



December 5, 2011

IRON CITY ENTERPRISES, INC.
TOM NEMETZ
N 2404 HWY. 41
MENOMINEE MI 49858

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: IRON CITY ENTERPRISES, INC.
Product Name: SEPTIC, HOLDING OR PUMP
Model Number(s): 1250
(48 IN. L.L., 27.47 GAL/IN., 36 IN. MAX. DEPTH OF BURY, 631 G.P.D. WHEN USED AS
A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER; **TANK DIMENSIONS (OD) = 96.5 IN. L X 75.5 IN. W X 48 IN. H**)
Product File No: 20110356

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of JANUARY 2017.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Cast-A-SEAL Gasket as cast into wall.
- AS OF MARCH 1, 2009, SECTION COMM 84.10 WAS MODIFIED AND THE REVIEW OF EXTERIOR GREASE INTERCEPTORS AS A PLUMBING PRODUCT IS NO LONGER REQUIRED. REVIEW WILL BE CONDUCTED AT THE TIME OF PROJECT-SPECIFIC PLAN REVIEW.

IRON CITY ENTERPRISES, INC.

Page 2

December 5, 2011

Product File No:20110356

- **Bedding: Tanks must be placed on soils capable of bearing the weight of tank and its contents, when full. Soft soils or bedrock must have 3 inches of tamped material, sand or gravel, 100% of which passes ½ -inch screen.**
- **BACKFILL: Place backfill in uniform layers less than 24 inches thick. Backfill should be free of any large stones (greater than 3 inches in diameter) or other debris. [NPCA Best Practices]**

This approval supersedes the approval issued on 1/09/2007 under product file number 20070003.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070003.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

This letter is to inform you that on MARCH 1, 2009 revised chapters COMM 82 and 84 of the Wisconsin Administrative Code went into effect. The revisions include the deletion of the requirement for plumbing product approval for EXTERIOR GREASE INTERCEPTORS, s. Comm 84.10. REVIEW OF EXTERIOR GREASE INCEPTORS WILL BE CONDUCTED AT THE TIME OF PROJECT-SPECIFIC PLAN REVIEW.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
DSPS WEST, Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV