



December 27, 2011

STRATFORD HOMES LTD.  
STEVE SCHOENFUSS  
PO BOX 37  
STRATFORD WI 54484

Re: Description:        **PREFABRICATED PLUMBING SYSTEM**  
Manufacturer:        **STRATFORD HOMES LTD.**  
Product Name:        **PRE-FAB PLUMBING**  
Model Number(s):    **SH-10-96 S-6**  
Product File No:     **20110376**

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2017.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 25 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.

This approval supersedes the approval issued on November 16, 2006 under product file number 20060463.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060463.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: jerry.thompson@wi.gov